

Prysbby, Mike (DEQ)

From: Michael Glasgow <mglasgow@cityofflint.com>
Sent: Wednesday, June 10, 2015 10:37 AM
To: Prysbby, Mike (DEQ)
Subject: Re: Lead-Copper info
Attachments: Consumer Notice of Lead Results.docx

PPI*Personal
cell*

Mike,

To answer your questions:

1. I'm trying to compile the list.
2. There were a couple of Apartment residences that were used in the first sampling pool. These would be tier 2 sites the majority were Tier 1.
3. A copy of the consumer notice is attached below.
4. This was in response to a customer complaint, and it is a business. I would only use the Utility sink as a site if we are short a sample, and would be a Tier 3. This is not in our sample pool, but is served by lead service line.

On Tue, Jun 9, 2015 at 10:14 AM, Prysbby, Mike (DEQ) <PRYSBYM@michigan.gov> wrote:

Mike,

I was trying to contact you regarding Lead and Copper info that we may need. I don't have your cell number....and the WTP main phone was not switching over to the option to have my incoming call forwarded to the lab. I wish to discuss the following:

1. Basically, we need a listing of Flint's PB&CU sampling pool (around 120 sites) with the Tier designation (Tier 1, Tier 2, or Tier 3) and those sites with lead services. It is possible that you may have sent us this information last summer as part of revising the lead & copper monitoring program.
2. The lead & copper reporting form for the July 2014 – Dec 2014 monitoring period states that not all sites were Tier 1; however, the listing of all 100 locations on the subsequent pages show all locations being Tier 1. Please clarify
3. Please provide us a copy of the consumer lead notice that was mailed to each customer in your sampling pool....we only need a copy of one notice.

4. We have received 28 of the 100 samples for the Jan-June 2015 round of lead/copper monitoring. Four of the samples were above the lead action level; however the PURPOSE of monitoring for two of these was noted as "OTHER" instead of ROUTINE MONITORING. The address of these 2 locations are: 625 S. Grand Traverse (Utility Sink) and 625 S. Grand Traverse (Bathroom). Is this site part of the sampling pool or was this location sampled based on a customer complaint and/or concern?

Michael Prysby, P.E.

District Engineer

Office of Drinking Water and Municipal Assistance

517 290-8817

--

Mike Glasgow
Utilities Administrator
City of Flint

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270

Lansing, MI 48909

TEL: (517) 335-8184

FAX: (517) 335-8562



Sample Number

LF64282

Official Laboratory Report

Report To: **MIKE GLASGOW**
4500 N DORT HWY
FLINT MI 48505

Basement Not Trier?

System Name/Owner: **CITY OF FLINT**
Collection Address: **625 S GRAND TRAVERSE, FLINT**
Collected By: **MIKE GLASGOW**
Township/Well#/Section: **//**
County: **Genesee**
Sample Point: **BATHROOM**
Water System: **Treated Public Distribution System**

WSSN/Pool ID: **2310**
Source: **TYPE III**
Site Code:
Collector: **Public Water Supply Operator**
Date Collected: **05/15/2015 13:00**
Date Received: **05/20/2015 11:24**
Purpose: **Other**

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Copper	0.14	05/21/2015	0.05	1.3	EPA 200.8	7440-50-8
Lead	0.017	05/21/2015	0.001	0.015	EPA 200.8	7439-92-1

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminant Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contacts
Drinking Water Unit Mgr: Julia Pieper
Systems Mgmt. Unit Mgr: George Krisztian

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270

Lansing, MI 48909

TEL: (517) 335-8184

FAX: (517) 335-8562



Sample Number

LF64284

Official Laboratory Report

Report To: MIKE GLASGOW
4500 N DORT HWY
FLINT MI 48505

System Name/Owner: CITY OF FLINT
Collection Address: 625 S GRAND TRAVERSE, FLINT
Collected By: MIKE SARGENT
Township/Well#/Section: //
County: Genesee
Sample Point: UTILITY SINK
Water System: Treated Public Distribution System

WSSN/Pool ID: 2310
Source: TYPE III
Site Code:
Collector: Private Citizen
Date Collected: 05/18/2015 08:30
Date Received: 05/20/2015 11:24
Purpose: Other

Not Tien?

Not For Compliance

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Copper	0.14	05/21/2015	0.05	1.3	EPA 200.8	7440-50-8
Lead	0.020	05/21/2015	0.001	0.015	EPA 200.8	7439-92-1

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminant Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contacts
Drinking Water Unit Mgr: Julia Pieper
Systems Mgmt. Unit Mgr: George Krisztian

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562



**Sample Number
LF57732**

Official Laboratory Report

Report To: MIKE GLASGOW
4500 N DORT HWY
FLINT MI 48505

System Name/Owner: CITY OF FLINT
Collection Address: 1383 WASHINGTON AVE, FLINT
Collected By: ANTHONY PALLADENO
Township/Well#/Section: //
County: Genesee
Sample Point: KITCHEN
Water System: Treated Public Distribution System

WSSN/Pool ID: 2310
Source: Single Family Dwelling
Site Code:
Collector: Private Citizen
Date Collected: 03/09/2015 08:00
Date Received: 03/24/2015 11:05
Purpose: Routine Monitoring

*Past 14 days
Hold time
for Preservation*

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Copper	0.16	03/25/2015	0.05	1.3	EPA 200.8	7440-50-8
Lead	0.007	03/25/2015	0.001	0.015	EPA 200.8	7439-92-1

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

**Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603**

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminant Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contacts
Drinking Water Unit Mgr: Julia Pieper
Systems Mgmt. Unit Mgr: George Krisztian



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
212 BROWNING AVE
FLINT MI 48507

Sample Number: LLF54945

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 2/18/2015 7:15:00 AM
Arrival Date: 2/19/2015 11:13:00 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: LEANNE WALTERS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.104	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Tue Aug 4 14:16:40 EDT
2015*was whole house filter*

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003



P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Sample Number
LF57729

Official Laboratory Report

Report To: MIKE GLASGOW
4500 N DORT HWY
FLINT MI 48505

System Name/Owner:	CITY OF FLINT	WSSN/Pool ID:	2310
Collection Address:	212 BROWNING AVE, FLINT	Source:	Single Family Dwelling
Collected By:	MIKE GLASGOW	Site Code:	
Township/Well#/Section:	//	Collector:	Public Water Supply Operator
County:	Genesee	Date Collected:	03/18/2015 11:10
Sample Point:	KITCHEN	Date Received:	03/24/2015 11:05
Water System:	Treated Public Distribution System	Purpose:	Other

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Copper	Not detected	03/25/2015	0.05	1.3	EPA 200.8	7440-50-8
Lead	0.004	03/25/2015	0.001	0.015	EPA 200.8	7439-92-1

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U. S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

**Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603**

*Not 1st draw
whole house filter*

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminant Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contacts
Drinking Water Unit Mgr: Julia Pleper
Systems Mgmt. Unit Mgr: George Krisztian



Michigan Department of Environmental Quality

Replicate Laboratory Report for Lansing Drinking Water Laboratory

Owner/Location Information:

CITY OF FLINT
212 BROWNING AVE
FLINT MI 48507

Sample Number: LLF56229

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 2/25/2015 10:26:00 AM
Arrival Date: 3/6/2015 11:34:24 AM

Site Code:
Water Source: Single Family Dwelling
Sample Reason: Water Quality Problem
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Public Water Supply Operator
Collected By: MIKE GLASGOW

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-38-2	ARSENIC (TOTAL)	ND	0.002	mg/L	EPA 200.8
7440-39-3	BARIUM	0.01	0.01	mg/L	EPA 200.8
7440-41-7	BERYLLIUM	ND	0.0004	mg/L	EPA 200.8
7440-43-9	CADMIUM (TOTAL)	ND	0.0003	mg/L	EPA 200.8
7440-47-3	CHROMIUM (TOTAL)	ND	0.01	mg/L	EPA 200.8
7439-97-6	MERCURY	ND	0.0001	mg/L	EPA 200.8
7440-02-0	NICKEL	ND	0.01	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8
7440-36-0	ANTIMONY	ND	0.0006	mg/L	EPA 200.8
7782-49-2	SELENIUM (TOTAL)	ND	0.001	mg/L	EPA 200.8
7440-28-0	THALLIUM	ND	0.0002	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Thu Aug 27 09:25:58 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
212 BROWNING AVE
FLINT MI 48507

Sample Number: LLF59748

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 4/2/2015 8:00:00 AM
Arrival Date: 4/14/2015 11:07:48 AM

Site Code:
Water Source: Single Family Dwelling
Sample Reason: Other
Sample Point: Treated Public Distribution System
Point Description: PRE P O S
Collector: Private Citizen
Collected By: LEEANNE WALTERS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.11	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.707	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Thu Aug 27 09:27:00 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
2205 FLUSHING RD
FLINT MI 48504

Sample Number: LLF47179

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 11/19/2014 6:00:00 AM
Arrival Date: 11/21/2014 10:35:42 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: CHRIS BEATENHEAD

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.11	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 13:44:46 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
3814 WHITTER AVE
FLINT MI 48506

Sample Number: LLF47180

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 11/20/2014 6:45:00 AM
Arrival Date: 11/21/2014 10:35:42 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: BATHROOM
Collector: Private Citizen
Collected By: BRIAN URCH

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:28:35 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
3521 BENNETT AVE
FLINT MI 48505

Sample Number: LLF47541

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 11/21/2014 5:15:00 AM
Arrival Date: 11/26/2014 8:41:15 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: BRENT WRIGHT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:28:55 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1220 BEARD ST
FLINT MI 48503

Sample Number: LLF48387

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/3/2014 7:45:00 AM
Arrival Date: 12/5/2014 10:57:57 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ANTHONY CHUBB

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.06	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.010	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:33:11 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3718 DOLPHAINE LN
FLINT MI 48506

Sample Number: LLF48388

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/3/2014 4:30:00 AM
Arrival Date: 12/5/2014 10:57:57 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JON MOCHTY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:33:20 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2213 FLUSHING RD
FLINT MI 48504

Sample Number: LLF48389

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/3/2014 6:15:00 PM
Arrival Date: 12/5/2014 10:57:58 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: RYAN DAVIS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.10	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:33:31 EDT
2015



Michigan Department of Environmental Quality

*Replicate Laboratory Report for
Lansing Drinking Water Laboratory*

Owner/Location Information:

CITY OF FLINT
721 EAST ST APT #2
FLINT MI 48503

Sample Number: LLF49329

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/10/2014 6:30:00 AM
Arrival Date: 12/11/2014 2:53:18 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MELANIE POISSON

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.12	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.009	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:33:41 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1125 BARRIE AVE
FLINT MI 48507

Sample Number: LLF49330

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 6:30:00 AM
Arrival Date: 12/11/2014 2:53:20 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: DAVID TAYLOR

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:10:12 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
1505 WOODLAWN PARK DR
FLINT MI 48503

Sample Number: LLF49331

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/6/2014 9:30:00 AM
Arrival Date: 12/11/2014 2:53:22 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MARY LAZAR

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.005	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:10:33 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2622 WINDEMERE
FLINT MI 48503

Sample Number: LLF49332

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/7/2014 8:00:00 AM
Arrival Date: 12/11/2014 2:53:29 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MATT SELLY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.005	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:10:43 EDT
2015



Michigan Department of Environmental Quality

*Replicate Laboratory Report for
Lansing Drinking Water Laboratory*

Owner/Location Information:CITY OF FLINT
3517 BENNETT
FLINT MI 48506Sample Number: LLF49333

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/10/2014 7:00:00 AM
Arrival Date: 12/11/2014 2:53:31 PMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: RANDY FREEMAN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.003	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:10:57 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
927 KENSINGTON AVE
FLINT MI 48503

Sample Number: LLF49334

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 7:30:00 AM
Arrival Date: 12/11/2014 2:53:33 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: DENNIS FULLER

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.11	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:11:06 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1109 KENSINGTON
FLINT MI 48503

Sample Number: LLF49335

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/4/2014 8:11:00 AM
Arrival Date: 12/11/2014 2:53:35 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JASON LORENZ

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:11:14 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1901 MONTCLAIR AVE
FLINT MI 48503

Sample Number: LLF49336

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 7:15:00 AM
Arrival Date: 12/11/2014 2:53:36 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: BATHROOM
Collector: Private Citizen
Collected By: MICHAEL KELLY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.06	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:11:25 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
1809 LYNBROOK
FLINT MI 48507

Sample Number: LLF49337

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/4/2014 4:30:00 AM
Arrival Date: 12/11/2014 2:53:37 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: DAWN STEELE

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:11:37 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1130 SIMCOE AVE
FLINT MI 48507

Sample Number: LLF49338

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 5:50:00 AM
Arrival Date: 12/11/2014 2:53:39 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: KELLY PLUNKEY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.05	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:11:46 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
413 BURROUGHS AVE
FLINT MI 48507

Sample Number: LLF49339

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/4/2014 6:30:00 AM
Arrival Date: 12/11/2014 2:53:41 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: AMANDA TRUJILLO

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:11:55 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
2079 ZIMMERMAN
FLINT MI 48503

Sample Number: LLF49340

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/8/2014 7:00:00 AM
Arrival Date: 12/11/2014 2:53:42 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MICHAEL EVERETT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:12:11 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
2615 WESTWOOD PKWY
FLINT MI 48503

Sample Number: LLF49341

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/6/2014 6:24:00 AM
Arrival Date: 12/11/2014 2:53:43 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: LOUIS EMMERT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.28	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:12:20 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2441 NORBERT
FLINT MI 48504

Sample Number: LLF49342

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/8/2014 4:30:00 AM
Arrival Date: 12/11/2014 2:53:44 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: PAT SEALS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.06	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.008	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:12:28 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
711 KENSINGTON AVE
FLINT MI 48503

Sample Number: LLF49343

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/9/2014 7:00:00 AM
Arrival Date: 12/11/2014 2:53:45 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: DON WOLFE

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.003	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:12:40 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:CITY OF FLINT
2015 GOLD AVE
FLINT MI 48503

Sample Number: LLF49344

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/4/2014 8:00:00 AM
Arrival Date: 12/11/2014 2:53:46 PMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: BRIAN HAGGINS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:12:50 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
618 S MEADE ST
FLINT MI 48503

Sample Number: LLF49345

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/8/2014 7:12:00 AM
Arrival Date: 12/11/2014 2:53:48 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: LOIS M LEE

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:13:01 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2802 WESTWOOD PKWY
FLINT MI 48503

Sample Number: LLF49346

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 8:30:00 AM
Arrival Date: 12/11/2014 2:53:49 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MARY COE RYAN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.11	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:13:12 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1914 PENBROOK LN
FLINT MI 48507

Sample Number: LLF47542

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 11/20/2014 6:10:00 AM
Arrival Date: 11/26/2014 8:41:16 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: BATHROOM
Collector: Private Citizen
Collected By: KARL ADKINS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:29:10 EDT
2015



Michigan Department of Environmental Quality

*Replicate Laboratory Report for
Lansing Drinking Water Laboratory*

Owner/Location Information:

CITY OF FLINT
305 ALLENDALE PL
FLINT MI 48503

Sample Number: LLF47543

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 11/24/2014 8:00:00 AM
Arrival Date: 11/26/2014 8:41:16 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ROBERT CASE

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.13	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:29:24 EDT
2015



Michigan Department of Environmental Quality

*Replicate Laboratory Report for
Lansing Drinking Water Laboratory*

Owner/Location Information:CITY OF FLINT
518 FROST ST
FLINT MI 48504

Sample Number: LLF48383

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/1/2014 11:00:00 AM
Arrival Date: 12/5/2014 10:57:55 AMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: STEVEN TAYLOR

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:29:34 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3120 NORWOOD DR
FLINT MI 48503

Sample Number: LLF48384

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/2/2014 6:15:00 AM
Arrival Date: 12/5/2014 10:57:56 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: BATHROOM
Collector: Private Citizen
Collected By: TOM HUTCHINGS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:29:43 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1901 CRESTBROOK LN
FLINT MI 48507

Sample Number: LLF48385

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 11/25/2014 8:10:00 AM
Arrival Date: 12/5/2014 10:57:56 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MICHELLE JOYNER

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.07	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:29:53 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3727 MARYLAND AVE
FLINT MI 48506

Sample Number: LLF48386

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/3/2014 6:00:00 AM
Arrival Date: 12/5/2014 10:57:56 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JOSHUA FREEMAN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 14:30:04 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
860 SCHAFER ST
FLINT MI 48503

Sample Number: LLF49347

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/8/2014 4:30:00 AM
Arrival Date: 12/11/2014 2:53:50 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: DERRICK JONES

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.07	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:33:45 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1021 S FRANKLIN AVE
FLINT MI 48503

Sample Number: LLF49348

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 5:15:00 AM
Arrival Date: 12/11/2014 2:53:51 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ROBERT AGUIRRE

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:43:22 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:CITY OF FLINT
1616 DURAND
FLINT MI 48503

Sample Number: LLF49349

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 7:05:00 AM
Arrival Date: 12/11/2014 2:53:51 PMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: LYNNE HURAND

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.20	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:43:32 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2730 WESTWOOD PKWY
FLINT MI 48503

Sample Number: LLF49351

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/4/2014 7:00:00 AM
Arrival Date: 12/11/2014 2:53:52 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ELIZABETH MURPHY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.29	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.023	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:43:41 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1543 KEARSLEY PARK BLVD
FLINT MI 48506

Sample Number: LLF49352

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/4/2014 5:30:00 AM
Arrival Date: 12/11/2014 2:53:55 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JACKIE KOZLOWICZ

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:43:50 EDT
2015



Michigan Department of Environmental Quality

*Replicate Laboratory Report for
Lansing Drinking Water Laboratory*

Owner/Location Information:

CITY OF FLINT
2920 PARKSIDE DR
FLINT MI 48503

Sample Number: LLF49353

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 7:40:00 AM
Arrival Date: 12/11/2014 2:53:56 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JANICE HENRY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.22	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.010	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:43:59 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2721 WESTWOOD PKWY
FLINT MI 48503

Sample Number: LLF49354

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 9:15:00 AM
Arrival Date: 12/11/2014 2:53:56 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Other
Collected By: D J TRELA

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.11	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:44:10 EDT
2015



Michigan Department of Environmental Quality

*Replicate Laboratory Report for
Lansing Drinking Water Laboratory*

Owner/Location Information:

CITY OF FLINT
1002 DURAND ST
FLINT MI 48503

Sample Number: LLF49355

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/4/2014 3:00:00 PM
Arrival Date: 12/11/2014 2:53:57 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ANDREW EVERETT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.11	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:44:19 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:CITY OF FLINT
2560 THOMAS ST
FLINT MI 48504

Sample Number: LLF49356

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/4/2014 9:17:00 AM
Arrival Date: 12/11/2014 2:53:58 PMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JESSICA SANCHEZ

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:44:28 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
815 BRADLEY AVE
FLINT MI 48503

Sample Number: LLF49357

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/7/2014 7:45:00 AM
Arrival Date: 12/11/2014 2:54:00 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: BATHROOM
Collector: Private Citizen
Collected By: ELIZABETH IRELAND-CURTIS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.27	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.005	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:44:43 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
4013 BROWNELL BLVD
FLINT MI 48504

Sample Number: LLF49358

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/8/2014 8:15:00 AM
Arrival Date: 12/11/2014 2:54:01 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ADRIAN JONES

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.08	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:44:52 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2418 GOLD AVE
FLINT MI 48503

Sample Number: LLF49359

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/10/2014 4:15:00 AM
Arrival Date: 12/11/2014 2:54:02 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: KATHLEEN ADAMS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:45:05 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
626 COMMONWEALTH AVE
FLINT MI 48503

Sample Number: LLF49360

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 9:00:00 AM
Arrival Date: 12/11/2014 2:54:02 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: HARRIET KENWORTHY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.003	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:45:14 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
920 STOCKER AVE
FLINT MI 48503

Sample Number: LLF49361

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/9/2014 4:40:00 AM
Arrival Date: 12/11/2014 2:54:03 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MICHAEL TAYLOR

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:46:28 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
430 WESTCOMBE AVE
FLINT MI 48503

Sample Number: LLF49362

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/9/2014 9:00:00 AM
Arrival Date: 12/11/2014 2:54:04 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: ROBERT MACDONALD

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:46:40 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1623 NEOME DR
FLINT MI 48503

Sample Number: LLF49363

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/5/2014 6:38:00 AM
Arrival Date: 12/11/2014 2:54:05 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: TAMAR LEWIS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.07	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.007	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:46:48 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:CITY OF FLINT
3802 GOREY AVE
FLINT MI 48506

Sample Number: LLF49364

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/8/2014 10:00:00 AM
Arrival Date: 12/11/2014 2:54:06 PMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: SEVENA RODRIGUEZ

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.05	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:46:56 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:CITY OF FLINT
1720 DAVISON RD
FLINT MI 48506

Sample Number: LLF49365

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/4/2014 6:58:00 AM
Arrival Date: 12/11/2014 2:54:06 PMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: UTILITY RO
Collector: Private Citizen
Collected By: JOSHUA FREEMAN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.13	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:47:09 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
2110 MOUNTAIN AVE
FLINT MI 48503

Sample Number: LLF49366

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/8/2014 3:16:00 PM
Arrival Date: 12/11/2014 2:54:07 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: TIM COLLARDEY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.06	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.005	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:47:19 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2006 CLEMENT ST
FLINT MI 48504

Sample Number: LLF49367

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/3/2014 8:30:00 AM
Arrival Date: 12/11/2014 2:54:08 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: BATHROOM
Collector: Private Citizen
Collected By: THOMAS HERTZ

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.003	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:47:27 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2028 CORUNNA RD
FLINT MI 48503

Sample Number: LLF49368

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/7/2014 7:00:00 AM
Arrival Date: 12/11/2014 2:54:08 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: PAUL EVERETT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:47:37 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2829 YALE ST
FLINT MI 48503

Sample Number: LLF50201

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/10/2014 9:00:00 AM
Arrival Date: 12/18/2014 11:14:56 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: CHRIS BAKAN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 15:47:46 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
1914 W HOME AVE
FLINT MI 48504

Sample Number: LLF50202

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/15/2014 5:48:00 AM
Arrival Date: 12/18/2014 11:14:57 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: DAZARINE BURNETT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:22:36 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2920 N DEXTER ST
FLINT MI 48506

Sample Number: LLF50203

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/15/2014 7:00:00 AM
Arrival Date: 12/18/2014 11:14:57 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: DAVID FIELDER

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Defect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.07	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:22:56 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2810 KELLAR AVE
FLINT MI 48504

Sample Number: LLF50204

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/15/2014 9:40:00 AM
Arrival Date: 12/18/2014 11:14:57 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: DELORES KEITH

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:23:06 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3245 MONTANA AVE
FLINT MI 48506

Sample Number: LLF50205

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/15/2014 10:35:00 AM
Arrival Date: 12/18/2014 11:14:57 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: JAMES L MOTON

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:23:15 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3623 NORWOOD DR
FLINT MI 48503

Sample Number: LLF50206

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/15/2014 6:55:00 AM
Arrival Date: 12/18/2014 11:14:58 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: SUSAN SULLIVAN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:23:25 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:CITY OF FLINT
2801 REYNOLDS
FLINT MI 48503

Sample Number: LLF50207

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/8/2014 5:45:00 AM
Arrival Date: 12/18/2014 11:14:58 AMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: CALIX MARTINEZ

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:23:34 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3510 BRANDON ST
FLINT MI 48503

Sample Number: LLF50208

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/10/2014 7:00:00 AM
Arrival Date: 12/18/2014 11:14:58 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ERIC BOW

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.08	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.005	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:23:49 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2117 STANFORD AVE
FLINT MI 48503

Sample Number: LLF50209

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/11/2014 1:30:00 PM
Arrival Date: 12/18/2014 11:14:59 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: CHIMENE HILL

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.003	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:23:58 EDT
2015



Michigan Department of Environmental Quality

Replicate Laboratory Report for Lansing Drinking Water Laboratory

Owner/Location Information:

CITY OF FLINT
5806 LESLIE DR
FLINT MI 48504

Sample Number: LLF50210

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/12/2014 11:37:00 AM
Arrival Date: 12/18/2014 11:14:59 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: F L GREEN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:24:06 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:-
CITY OF FLINT
1809 W HOME AVE
FLINT MI 48504Sample Number: LLF50211

Sample/Collection Information:-
WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/11/2014 6:20:00 AM
Arrival Date: 12/18/2014 11:14:59 AMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: SHIRLEY JEAN WILLIAMS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:24:14 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1414 STONE ST
FLINT MI 48503

Sample Number: LLF50212

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/12/2014 6:00:00 AM
Arrival Date: 12/18/2014 11:15:00 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: JAMEY L SMITH

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:24:25 EDT
2015



Michigan Department of Environmental Quality

Replicate Laboratory Report for Lansing Drinking Water Laboratory

Owner/Location Information:

CITY OF FLINT
2006 AITKEN AVE
FLINT MI 48503

Sample Number: LLF50721

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/16/2014 7:30:00 AM
Arrival Date: 12/23/2014 1:34:45 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: NORMAN GRAHAM

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:24:33 EDT
2015



Michigan Department of Environmental Quality

*Replicate Laboratory Report for
Lansing Drinking Water Laboratory*

Owner/Location Information:

CITY OF FLINT
3131 WOLCOTT
FLINT MI 48504

Sample Number: LLF50722

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/17/2014 8:11:00 AM
Arrival Date: 12/23/2014 1:34:46 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: KATHY MCGAUGHY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:24:42 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
983 GAINEY AVE
FLINT MI 48503

Sample Number: LLF50723

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/17/2014 6:15:00 AM
Arrival Date: 12/23/2014 1:34:46 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JOANN CUSIC

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.10	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:24:50 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
2806 NORBERT ST
FLINT MI 48504

Sample Number: LLF50724

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/18/2014 6:30:00 AM
Arrival Date: 12/23/2014 1:34:46 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ARIEL DANTZLER

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:24:58 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
912 CRAWFORD ST
FLINT MI 48507

Sample Number: LLF50725

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/15/2014 5:30:00 AM
Arrival Date: 12/23/2014 1:34:47 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MICHAEL S REITER

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.11	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:25:10 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:CITY OF FLINT
4024 STERLING
FLINT MI 48504Sample Number: LLF50726

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/16/2014 9:30:00 AM
Arrival Date: 12/23/2014 1:34:47 PMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: BETTY WESLEY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:25:18 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3737 WORCHESTER DR
FLINT MI 48503

Sample Number: LLF50727

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/16/2014 6:45:00 AM
Arrival Date: 12/23/2014 1:34:47 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: SHERRI TOLBERT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.14	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:25:26 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
1100 STOCKTON ST
FLINT MI 48503

Sample Number: LLF50728

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/16/2014 5:00:00 AM
Arrival Date: 12/23/2014 1:34:48 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JOHN E ROSE

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.006	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:25:34 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
1725 LINCOLN AVE
FLINT MI 48503

Sample Number: LLF50729

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/21/2014 6:00:00 AM
Arrival Date: 12/23/2014 1:34:48 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MICHELE IGRAM

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:25:42 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3139 COLORADO
FLINT MI 48506

Sample Number: LLF50730

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/16/2014 6:10:00 AM
Arrival Date: 12/23/2014 1:34:48 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: TIM ABRAHAM

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:25:50 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1401 GAINEY AVE
FLINT MI 48503

Sample Number: LLF50731

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/20/2014 8:30:00 AM
Arrival Date: 12/23/2014 1:34:48 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: LUCY LAFRENIERE

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:25:58 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
2730 COVENTRY CT
FLINT MI 48503

Sample Number: LLF50732

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/19/2014 9:30:00 AM
Arrival Date: 12/23/2014 1:34:49 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: SUSAN HARAISTY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:26:09 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:CITY OF FLINT
709 FROST ST
FLINT MI 48504

Sample Number: LLF50733

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/19/2014 9:00:00 AM
Arrival Date: 12/23/2014 1:34:49 PMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: MAURICCI GUYNN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:26:16 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:CITY OF FLINT
2307 RADCLIFFE
FLINT MI 48503

Sample Number: LLF50734

Sample/Collection Information:WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/20/2014 7:08:00 AM
Arrival Date: 12/23/2014 1:34:49 PMSite Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ANDREW ARMSTRONG

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.08	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.037	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:26:27 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
224 E COURT ST APT 508
FLINT MI 48502

Sample Number: LLF50735

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/15/2014 6:45:00 AM
Arrival Date: 12/23/2014 1:34:50 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: S J DAUIDEK

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:26:36 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3440 RANGELEY
FLINT MI 48503

Sample Number: LLF50736

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/13/2014 8:57:00 AM
Arrival Date: 12/23/2014 1:34:50 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JACQUELINE WATKINS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:26:45 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3808 BROWNELL BLVD
FLINT MI 48504

Sample Number: LLF50737

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/16/2014 8:00:00 AM
Arrival Date: 12/23/2014 1:34:50 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: COY BRIDGES

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.09	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:26:53 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:CITY OF FLINT
1006 KENSINGTON
FLINT MI 48503

Sample Number: LLF50738

Sample/Collection Information:

WSSN: 02310

County: Genesee

Township:

Section:

Well #:

Collection Date: 12/19/2014 6:15:00 AM

Arrival Date: 12/23/2014 1:34:51 PM

Site Code:

Water Source: Public Community Water Supply

Sample Reason: Routine Monitoring

Sample Point: Treated Public Distribution System

Point Description: KITCHEN

Collector: Private Citizen

Collected By: FRANCES HOLMES

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:27:06 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
2517 DELAWARE AVE
FLINT MI 48506

Sample Number: LLF50824

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/18/2014 5:30:00 AM
Arrival Date: 12/29/2014 10:28:00 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: RUSS BEDFORD

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	0.20	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.005	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:27:16 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1810 W HOBSON AVE
FLINT MI 48504

Sample Number: LLF50825

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/21/2014 6:00:00 AM
Arrival Date: 12/29/2014 10:28:05 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: MR AND MRS VERNON

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:27:25 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
5805 LESLIE DR
FLINT MI 48504

Sample Number: LLF50826

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/21/2014 7:00:00 AM
Arrival Date: 12/29/2014 10:28:09 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: SHIRLEY HILL

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.002	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:27:32 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1721 CHELSEA CIRCLE
FLINT MI 48503

Sample Number: LLF50827

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/22/2014 6:25:00 AM
Arrival Date: 12/29/2014 10:28:11 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: CHERYL CHRISTOFF

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:27:41 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
912 WALDMAN AVE
FLINT MI 48507

Sample Number: LLF50828

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/23/2014 6:25:00 AM
Arrival Date: 12/29/2014 10:28:13 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: PAMELA GALE

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:27:51 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
3082 LANNING DR
FLINT MI 48506

Sample Number: LLF50829

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/24/2014 6:45:00 AM
Arrival Date: 12/29/2014 10:28:13 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: CONSTANCE L ST GERMAIN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:27:59 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
2515 CHICAGO BLVD
FLINT MI 48503

Sample Number: LLF50830

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/26/2014 8:15:00 AM
Arrival Date: 12/29/2014 10:28:13 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: MARY SEVERN

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.006	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:28:07 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
742 LINCOLN AVE
FLINT MI 48507

Sample Number: LLF50831

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/26/2014 9:30:00 AM
Arrival Date: 12/29/2014 10:28:14 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: DANA V STIF

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.003	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:28:15 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1910 RAMSAY BLVD
FLINT MI 48503

Sample Number: LLF50929

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/20/2014 7:00:00 AM
Arrival Date: 12/30/2014 10:43:18 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: MAIN BATHR
Collector: Private Citizen
Collected By: CAROL B CRAWFORD

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:28:29 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3009 MONTANA AVE
FLINT MI 48506

Sample Number: LLF51179

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/29/2014 3:12:00 PM
Arrival Date: 1/6/2015 11:03:34 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: MEMSSA BECKELIC

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:28:55 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1223 CAMPBELL ST
FLINT MI 48507

Sample Number: LLF51180

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/30/2014 8:00:00 AM
Arrival Date: 1/6/2015 11:03:35 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: JOSH DEMOTT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.001	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:29:06 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3821 DELAWARE
FLINT MI 48506

Sample Number: LLF51181

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/27/2014 9:00:00 AM
Arrival Date: 1/6/2015 11:03:35 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: THOMAS R KERBEY

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:29:16 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
1651 WOODLAWN PARK
FLINT MI 48503

Sample Number: LLF51182

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/29/2014 5:42:00 AM
Arrival Date: 1/6/2015 11:03:35 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: KIRWIN KINNEE

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:29:25 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
1911 CORRY ST
FLINT MI 48506

Sample Number: LLF51183

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/30/2014 8:10:00 AM
Arrival Date: 1/6/2015 11:03:36 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: DAWN WILLIAMS

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:29:34 EDT
2015



Michigan Department of Environmental Quality

**Replicate Laboratory Report for
Lansing Drinking Water Laboratory**

Owner/Location Information:

CITY OF FLINT
3507 DEARBORN AVE
FLINT MI 48507

Sample Number: LLF51184

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/30/2014 9:15:00 AM
Arrival Date: 1/6/2015 11:03:36 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: SUZANNE EREMA

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.006	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:29:44 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
3829 IVAN HOE AVE
FLINT MI 48506

Sample Number: LLF51185

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/29/2014 3:00:00 PM
Arrival Date: 1/6/2015 11:03:36 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ADREAN ELMOT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:29:53 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1559 CHEVROLET AVE
FLINT MI 48504

Sample Number: LLF51186

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/30/2015 7:00:00 AM
Arrival Date: 1/6/2015 11:03:00 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: SAMUEL ANCIRA

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.009	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Wed Aug 26 16:30:03 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
928 DURAND
FLINT MI 48503

Sample Number: LLF49350

Sample/Collection Information:

WSSN:
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/7/2014 7:00:00 AM
Arrival Date: 12/11/2014 2:53:52 PM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: TONY EVERETT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	ND	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Thu Aug 27 14:17:13 EDT
2015



Michigan Department of Environmental Quality

***Replicate Laboratory Report for
Lansing Drinking Water Laboratory***

Owner/Location Information:

CITY OF FLINT
1805 RAMSAY BLVD
FLINT MI 48503

Sample Number: LLF50928

Sample/Collection Information:

WSSN: 02310
County: Genesee
Township:
Section:
Well #:
Collection Date: 12/27/2014 7:00:00 AM
Arrival Date: 12/30/2014 10:43:18 AM

Site Code:
Water Source: Public Community Water Supply
Sample Reason: Routine Monitoring
Sample Point: Treated Public Distribution System
Point Description: KITCHEN
Collector: Private Citizen
Collected By: ANTHONY EVERETT

<u>CasNo</u>	<u>Analyte</u>	<u>Result</u>	<u>Detect</u>	<u>Units</u>	<u>Method</u>
7440-50-8	COPPER (RECOVERABLE)	ND	0.05	mg/L	EPA 200.8
7439-92-1	LEAD (TOTAL)	0.004	0.001	mg/L	EPA 200.8

Laboratory Comments:

By authority of PA 368 of 1978 as amended.

Print Date: Thu Aug 27 14:18:23 EDT
2015