

Olszewski, Rosemarie (DEQ)

From: Prysby, Mike (DEQ)
Sent: Friday, February 06, 2015 1:48 PM
To: emurphy@cityofflint.com
Cc: 'bwright@cityofflint.com'
Subject: Flint River Source Water Assessment
Attachments: Flint River Source Water Assess..doc

Elizabeth,

Attached is a copy of the Flint River Source Water Assessment report for your information. Water treatment plant staff should have a copy of this report, if not, please provide them with a copy.

Michael Prysby, P.E.
District Engineer
Office of Drinking Water and Municipal Assistance
517 290-8817

**Source Water Assessment Report for the
City of Flint Water Supply
Flint River Emergency Intake
February 2004**



*City of Flint Water Treatment Plant,
Flint, Michigan*

Prepared for:

City of Flint Water Supply; WSSN 2310

Prepared by:

**U.S. Geological Survey, Water Resources Division, Michigan District
Michigan Department of Environmental Quality, Water Division
City of Flint Water Utilities Department**

Michigan Source Water Assessment Report 54

Executive Summary

The purpose of the Source Water Assessment is to analyze the sensitivity and determine susceptibility of a community's source of drinking water to potential sources of contamination.

*Sensitivity is determined from the natural setting of the source water (raw water to the water treatment plant), and indicates natural protection afforded the source water. Using procedures established in the Great Lakes Protocol, Michigan Source Water Assessment Program, the **emergency** intake for the Flint Water Treatment Plant has a very high degree of sensitivity to potential contaminants. When the effects of agricultural and urban runoff in the Flint River watershed are considered, the Flint intake is categorized as very highly sensitive.*

*Susceptibility identifies factors within the community's source water area that may pose a risk to the water supply. The susceptibility determination provides information with respect to listed facilities and land areas within the source water area that should be given greater priority and oversight in implementing a source water protection program. The source water area for the Flint **emergency** intake includes 96 potential contaminant sources, 16 listed potential contaminant sources within the susceptible area, plus urban and agricultural runoff from the Flint River watershed into the Flint River. The potential contaminant sources, in combination with the very highly sensitive intake, indicate that the Flint **emergency** intake source water is very highly susceptible to potential contamination.*

*The Flint **emergency** intake source water is categorized as very highly susceptible, given land uses and potential contaminant sources within the source water area. However, it is noted that when operating, the City of Flint Water Treatment Plant has effectively treated this source water to meet drinking water standards. The City of Flint has instituted pollution prevention programs, but should be cognizant of additional potential threats to its source of drinking water that are identified in this report. This report explains the background and basis for these determinations.*

Using this Assessment

Clean, safe drinking water is fundamental to the viability of any community. Protecting the drinking water source is a wise and relatively inexpensive investment in your community's future. The overall intent of this assessment is to provide background information for your community to use in developing a local source water protection program. The assessment benefits your community by providing the following:

- *A basis for focusing limited resources within the community to protect the drinking water source(s).*

The assessment provides your community with information regarding activities within the **source water area (SWA)** that directly affect your water supply. It is within this SWA that a spill or improper use of **potential contaminants** may cause these contaminants to migrate toward the water **intake**. By examining where the source waters are most susceptible to contaminants, and where potential contaminants are located, the assessment clearly illustrates the potential risks that should be addressed.

- *A basis for informed decision-making regarding land use within the community.*

The assessment provides your community with a significant amount of information regarding where your drinking water comes from (the source) and what the risks are to the quality of that source. Knowing where the resource is allows your community planning authorities to

make informed decisions regarding proposed land uses within the SWA that are compatible with both your drinking water resource and the vision of growth embraced by your community.

- ***A basis for dealing with future regulations.***

The assessment has been designed to functionally meet proposed requirements for surface-water supplies. Information needed to address regulatory needs and requirements has been collected and made available to your community through this report.

This source water assessment also provides the basis for a locally developed, voluntary source water protection program. Communities interested in voluntarily developing source water protection programs should contact the Michigan Department of Environmental Quality (MDEQ) or visit the Department web page at <http://www.deq.state.mi.us>.

Introduction

In 1996, Congress amended the **Safe Drinking Water Act** and provided resources for state agencies to conduct source water assessments by identifying SWAs, analyzing the **sensitivity** of the source to natural conditions, conducting contaminant source inventories, and determining the **susceptibility** of the source to potential contamination. Delineations, sensitivity analyses, contaminant inventories, and susceptibility determinations comprise a "source water assessment." Assessments will be completed for every public water supply source in Michigan. To support this effort, the MDEQ Water Division established a partnership with the U.S. Geological Survey (USGS) to develop a method for conducting source water assessments for surface water supplies (Sweat and others, 2000; Sweat and others, 2001).

The requirements for public water supplies in Michigan to meet United States Environmental Protection Agency (USEPA) **maximum contaminant levels (MCLs)** provide some degree of assurance of safe drinking water; however, all systems are vulnerable to potential contamination. One of the best ways to ensure safe drinking water is to develop a local program designed to protect the source of drinking water against potential contamination. Not only does this add a margin of safety, but it also raises the awareness of consumers and/or the community of the risks of drinking water contamination. It is expected that source water assessment results will provide a basis for developing a source water protection program.

Background

Flint is located in Genesee County, about 55 miles northwest of Detroit, Michigan (fig. 1). The city of Flint water supply serves a population of 125,000. In 1967, the city connected to the Detroit Water and Sewage Department (DWSD) water supply and the Flint Water Treatment Plant (WTP) was placed on stand-by operation. The city is required by the MDEQ to maintain this treatment facility for reliability since the city obtains treated water through a single pipeline from the DWSD Lake Huron WTP which is subject to interruption of service. The present intake at the Flint WTP was constructed in 1948 and consists of a concrete box structure on the edge of the Flint River. The intake structure has a bottom elevation of 700.00 and connects through a 72-inch concrete pipe to the low service pump station. Low service pumps lift the river water through the WTP processes of conventional treatment and lime-soda softening.



***Flint WTP Emergency, Flint River Intake Structure
(Viewed from downstream)***

Treatment at the plant includes the addition ferric chloride as a coagulant, lime and soda ash for softening, chlorine for disinfection, and fluoride addition for dental health.

Water treatment plants are periodically inspected to identify construction, maintenance, operational or source defects that could make them vulnerable to contamination, particularly from contaminants that are microbial in nature, such as fecal coliforms. Water suppliers are provided a sanitary survey report that notes deficiencies in the system, and the State may direct the system to make necessary corrections. The sanitary survey is an important part of a safe drinking water program.

Climate

The Flint water supply is located in the central Lower Peninsula hydrologic province (Rheaume, 1991), in the Flint River watershed (USGS, 1974, 1982). The region experiences temperate summers with moderate winters. The Flint Bishop International Airport Weather Bureau station reports that the average annual precipitation for the climatic years 1887-2001 was 30.28 inches and the average from the past 5 years is 31.42 inches (NOAA, 2001), with about 13 percent of that as snowfall between November and March. Annual average runoff for the Flint SWA, extrapolated from Miller and Twenter (1986, fig. 1) is 9 to 10 inches.

Source Water Area Geology and Hydrology

The study area for evaluating the extent of the Flint emergency intake SWA includes the upper reaches of the Flint River watershed (fig. 1). Flint is located roughly in the middle of the Flint River watershed. The



Flint River – Source Water for City of Flint WTP

SWA consists of lacustrine clays and silts; end moraines of coarse- and medium-textured till; fine-, medium-, and coarse-textured glacial tills; and postglacial alluvium. The SWA is underlain by Bayport Limestone, Marshall Sandstone and mixed shales, sandstones, and limestones of the Saginaw and Michigan Formations (Martin, 1955; Milstein, 1987). Soils underlying the Flint SWA are primarily associations of the Blount, Boyer,

Brookston, Capac, Ceresco, Celina,

Chelsea, Cohoctah, Conover, Del Ray, Kibbie, Lapeer, Lenawee, McBride, Metea, Miami, Montcalm, Sloan, Spinks series (U.S. Department of Agriculture, 1961; BASINS, 1998; MIRIS, 2000). They include loams, loamy sands, fine sandy loams, silty clay and muck.

Soil permeability is based on the calculated time of travel, in inches per hour (in/hr), for water to move vertically through a saturated soil zone. Soil thickness and permeability values are available in soil survey reports published by the National Cooperative Soil Survey and U.S. Department of Agriculture (1982, 1992, 1993, also 2 county reprints in press). Permeability ranges from less than 0.06 in/hr, rated as very slow, to more than 20 in/hr, rated as very rapid.

Source-water Area (SWA) for the City of Flint Emergency Water Supply




Figure 1. Source-water area (SWA) for the evaluation of the Flint emergency intake, Flint, MI.



Mott Lake and Dam on Flint River upstream of Flint WTP

3.1 in/hr (Schneider and Erickson, undated, series of 5 maps; BASINS, 1998; MIRIS, 2000). Soil permeability ranges from moderately slow in the northeastern portion of the SWA to moderate over the eastern portion of the SWA to moderately rapid throughout the central and western portions of the SWA, and rapid around the Flint River (fig. 2; U.S. Department of Agriculture, 1961; BASINS, 1998; MIRIS, 2000). Areas adjacent to the Flint River are underlain by highly sensitive drift lithologies, whereas the remainder of the SWA is underlain by least sensitive drift lithology (Lusch and others, 1992).

The Flint SWA contains an area of about 237 square miles (mi²). There are is one operable gage within the Flint SWA and a Flint River gage which operates approximately 9 miles downstream from the Flint Emergency Intake. Between 1932 and 2002 discharge has been recorded at this station by the USGS (Blumer and others, 2002). Annual mean discharge at the Flint River at Flint gauging station was 339 cubic feet per second (cfs) between 1932 and 2001, and ranged from 153 to 1258

cfs. Velocity measured at this stream gage was used to estimate the distance in which contaminants could travel within 24 hours, or the 24-hour time-of-travel (TOT) for this area on the Flint River. The distance calculated for the 24-hour TOT was approximately 27 miles.

Very slowly permeable soils significantly reduce the movement of water through the soil zone and, as a result, allow greater time for natural degradation of contaminants. However, such soils also provide for rapid overland transport of contaminants directly to receiving waters, which in turn may affect the water supply intake. Erosion and transport of soils by surface waters can cause an increase in turbidity. In contrast, very rapidly permeable soils allow for rapid infiltration and passage through the soil zone from the surface. Such soils potentially allow rapid transport of contaminants with minimal contact-time available for contaminant breakdown.

Mean, area-weighted, depth-integrated permeabilities for the Flint SWA range from 0.6 to as much as 7.8 in/hr. The mean permeability is



Kearsley Lake and Dam on Kearsley Creek Upstream of Discharge to Flint River and Flint WTP Emergency Intake

Soil Permeability for the Flint Source-water Area, Flint, MI




Figure 2. Soil permeability for the Flint emergency water-supply intake SWA. Flint, MI.

History of Raw Water Quality at the Source

Public water supplies are required to routinely monitor raw water quality for selected parameters to optimize treatment, and to monitor treated water quality for a list of contaminants that is determined by MDEQ and the Safe Drinking Water Act. A detection of any contaminant may indicate that a pathway exists for contaminants to reach the intake. It is important to realize that the results from a given sample only provide information regarding the water quality at the time the sample was collected. Water quality can change with time for a number of reasons. The fact that a water sample does not contain contaminants is no guarantee that contamination will not occur in the future. Conversely, the detection of a contaminant in the past does not indicate that it will occur in the future.

The Flint WTP records for the last 3 years of routine operation, 1965-1967 show that water use fluctuated between 34.4 and 46.5 million gallons per day (MGD), with an average daily use of 38.5 MGD. Raw water quality reported for these three years ranged from 5 to 183 nephelometric turbidity units (NTU) for turbidity, 203 to 375 mg/l total hardness as CaCO₃, 116 to 235 mg/l alkalinity as CaCO₃, 16 to 46 mg/l chlorides and 8.2 to 8.5 units for pH. Precipitation events were noted to increase turbidity and lower hardness. An analysis of flow duration for the Flint River and source water chemistry would probably indicate that there may be an indirect correlation between turbidity, suspended sediments, and coliforms and high flows associated with spring snowmelt and precipitation runoff events.

In recent years, the Flint WTP has undergone operational and process improvements for water treatment. Raw water quality during these testing periods when the WTP was operating but discharging to waste are noted in the table below.

Date of Tests	Turbidity (NTU)	Total Organic Carbon (mg/l)	pH (pH units)	Alkalinity (mg/l)	Hardness (mg/l)
12/5-7/2000	4.2	8.75	7.8	249	324
1/16-18/2001	2.4	8.5	7.7	275	363
3/20-21-2001	5.4	N/A	7.9	196	266
4/16-18/2001	7.6	8.6	8.2	213	284

Source Water Assessment Methodology

Technical guidelines for completing source water assessments are contained in the Michigan Source Water Assessment Program, Assessment Protocol for Great Lakes Sources (Protocol) (MDEQ, 1999, Appendix L) available at <http://www.deq.state.mi.us/dwr>. In general, an assessment is a process for evaluating a drinking water supply and the potential for its treated water to exceed an MCL due to raw water contamination. A source water assessment considers the SWA, potential sources of contamination within the SWA, conditions of the water supply intake, and susceptibility to contaminants in order to identify potential risks to drinking water quality. Although the Protocol provides the minimum requirements and instructions on how to conduct an assessment, each water supply is unique with respect to how the process is carried out, due to local conditions and information. Sweat and others (2000, 2001) have developed and documented the methodology used in the preparation of this assessment.

Delineating Source Water Areas

Delineation of the SWA is accomplished by using geographic information system (GIS) software to map the watershed(s) that have the potential to affect source water at the intake. Using information from the water supply, a critical assessment zone (CAZ) is defined for the intake (MDEQ, 1999, Appendix L). A buffer is then created along any shoreline intersected by the CAZ, and from the edge of the CAZ to the mouth of any river(s) that might influence the intake. Finally, the buffer is extended along the shoreline of any river(s) that might influence the intake, from the mouth of the river to its headwaters. The area defined by the CAZ, river and shoreline buffers is termed the susceptible area. The susceptible area within the SWA defines locations where a water supply should focus its management strategies and resources to benefit the drinking water resources.

Using the Great Lakes Protocol and the Flint water supply information:

- The CAZ for the Flint intake is assigned as 3,000 ft since the intake is located in an inland river (fig. 3).
- The susceptible area along the shoreline is determined to be: A distance of 300 ft inland along the banks of the Flint River and its tributaries (fig. 4).




Figure 53. Surface-water Source Sensitivity Analyses and Susceptibility Determination for the Ann Arbor Flint emergency water-treatment-plant source-water areas.

Contaminant Source Inventory

Past, current, and potential future sources of contaminants were inventoried to identify several categories of potential sources of contaminants including microorganisms (bacteria, oocysts, and viruses), inorganic compounds (nitrates and metals), organic compounds (solvents, petroleum compounds, pesticides), and disinfection by-product precursors (trihalomethanes, haloacetic acids).

It is important to remember that sites and areas identified by this process are only potential contaminant sources used and managed properly. In addition, assumptions were made about particular types of land uses and risks associated with those land uses. Assumptions are discussed further in the results portion of this report.

The process for completing the inventory included several steps, which are summarized as follows:

1. Reviewed readily available land use maps and historical/current aerial photographs.
2. Plotted relevant information from applicable state and federal regulatory databases including the following lists:
 - MDEQ leaking underground storage tank (LUST) sites;
 - MDEQ registered underground storage tank (UST) sites;
 - MDEQ Environmental Cleanup Site Information System (ECSI) sites;




Figure 4. Critical Assessment Zone (CAZ) for the Flint emergency water-supply intake, Flint, MI.

- ·MDEQ Source Information System (for water discharge permit sites including National Pollutant Discharge Elimination System (NPDES) permits, Water Pollution Control Facility (WPCF) permits, storm water discharge permits, and on-site sewage (septic) system permits);
 - ·MDEQ Underground Injection Control (UIC) database;
 - ·MDEQ Active Solid Waste Disposal Permits list;
 - ·Michigan Department of Transportation (MDOT) - Hazardous Materials database;
 - ·State Fire Marshall registry of above-ground fuel storage tank sites;
 - ·State Fire Marshall Hazardous Material Handlers and Hazardous Material Incidents (HAZMAT) sites;
 - ·U.S. EPA BASINS software, version 2.1.
 - ·U.S. EPA Envirofacts database;
 - ·U.S. EPA Resource Conservation Recovery Act (RCRA) generators or notifiers list;
 - ·U.S. EPA RCRA Treatment, Storage, and Disposal Facility (TSDF) Permits list;
 - ·U.S. EPA National Priorities List (NPL);
 - ·U.S. EPA Comprehensive Environmental Response, Compensation and Liability Information System (CERCLA) List;
 - ·U.S. EPA RCRA Corrective Action Activity List (CORRACTS);
 - ·U.S. Department of Transportation (DOT) Hazardous Materials Information Reporting System (HMIRS);
 - ·U.S. EPA Toxic Chemical Release Inventory System (TRIS); and
 - ·U.S. EPA Oil Pollution Act of 1990 Spill Response Atlas
3. Met with public water supply and community officials on June 11, 2003 to identify potential sources not listed elsewhere in databases or on maps and completed a preliminary inventory form to be used in completing the SWA base map. Subsequent contacts by email and telephone on numerous occasions to request additional data, clarify data, and discuss results.
 4. Land use and/or ownership (for example, residential/municipal; commercial/industrial; agricultural/forest; and other land uses) was mapped and evaluated in relation to PCS, soil characteristics, and proximity to the intake(s).
 5. Conducted an informal field inventory to locate additional PCS.
 6. Completed final inventory form of PCS and plotted locations of PCS on the base map.

The purpose of the inventory is three fold: first, to provide information on the location of PCS, especially those within the susceptible area; second, to provide an effective means of educating the public about PCS; and third, to provide a reliable basis for developing a management plan to reduce potential contaminant risks to the Flint water supply.

The inventory process attempts to identify potential point-source contaminants within the SWA. It does not include an attempt to identify specific potential contamination problems at specific sites, such as facilities that do not safely store potentially hazardous materials. However, assumptions were made about particular types of land use. For example, it is assumed that rural residences associated with farming operations have specific potential contamination sources such as fuel storage, chemical storage and mixing areas, and machinery repair shops. It should also be noted that although the inventory depicts existing agricultural uses (crops grown), these are likely to undergo continual change due to normal crop rotation practices. What is irrigated farmland now may be non-irrigated farmland next year, or vice versa.

The results of the inventory were analyzed in terms of current, past, and future land uses and their relationship to the susceptible area and the supply intake. In general, land uses and PCS that are closest to the supply intake pose the greatest threat to a safe drinking water supply. Inventory results are summarized in table 1, and are shown on figure 5.

Many PCS are readily identifiable because they have a single discharge point, and often a permit is required for these discharges. However, other PCS have diffused, poorly defined discharge locations. These are known as non-point discharges because they occur over large areas and may not be quantifiable by readily accepted methods. These non-point source discharges are difficult to identify and control, and consequently to quantify, yet they are a major source of water pollution (Carpenter and others, 1998). Non-point sources also include atmospheric deposition over water and land, and include urban, rural, and

Table 1. Potential contaminant sources in the source water area

Type of Potential Contaminant Source (PCS)	Number of PCS	Number of PCS in Susceptible Area
Hazardous or solid waste site permits	71	11
Industrial facility discharge site permits	9	3
National priority list sites	1	0
Permit compliance system	12	2
Toxic release inventory permits	3	0
TOTALS	96	16

agricultural runoff from areas such as lawns, golf courses, farm fields, pastures, parking lots, and roadways. Runoff from these areas can contain many types of pollutants including sediments, metals, organic and inorganic chemicals, viral and bacterial pathogens, pharmaceuticals, and animal wastes. Transportation also represents a non-point source of contamination. Trucking and railroads transport potential contaminants through the SWA. An accident causing a spill could lead to potential contaminants entering a storm sewer, or in the case of boaters or rail transportation, directly to the Flint River. Petroleum pipeline crossing the upper reaches of the Flint River also pose contaminant threats.

Non-point sources of concern to the Flint water supply are primarily from storm sewers and from industrial, commercial, and residential sources in the SWA and communities upstream of the intake. A railroad bridge immediately upstream in the CAZ of the intake carries occasional train traffic described as hazardous. The West Boulevard storm sewer which discharges in the CAZ provides drainage to the Flint River from an industrialized area.

The Michigan Department of Agriculture is working to identify dairies and concentrated animal feedlots (greater than 1000 animal units) in the Flint River watershed upstream of the intake.



Railroad Trestle over Flint River Immediately Upstream of Flint WTP

The U.S. Environmental Protection Agency (USEPA) has identified one impaired water body in the Flint SWA on its Clean Water Act 303(d) list. The parameter of concern within the Holloway Reservoir is fish consumption advisories for PCBs. An additional impaired water body exists upstream of the SWA but not within the SWA itself. This water body is the collective of unnamed drains in Metamora, and the parameters of concern are untreated sewage discharge and pathogens (MDEQ, 2002).

In general, PCS within the susceptible area pose greater risks than those outside the susceptible area. The presence of PCS within the SWA indicates potential sources of chemicals that could, if improperly managed or released, impact the water quality at the intake. Small quantities of these chemicals, in some

Contaminant Source Inventory for the Flint Emergency Water Supply Intake, Flint, MI




Figure 5. Potential Contaminant Sources in City of Flint Source Water Area, Flint, Michigan

cases less than a liter, can significantly affect the supply. Also of concern is the location and distribution of these sources with respect to highly permeable soils. The susceptible area consists of primarily agricultural and forested land with some urban areas. Overlaying the PCS locations and the moderately rapid to rapidly permeable soil map for the Flint SWA indicates that 21 of the located PCS are located on or very near to areas with moderately rapid to rapidly-permeable soils. All PCS within the SWA should be addressed; the susceptibility determination, however, provides the water supply with the tools to focus resources where the greatest risk occurs. The results of the PCS inventory performed for Flint water supply is shown on figure 5 and is summarized as a function of PCS locations relative to the susceptible area. The inventory results indicate that there are 7 PCS, holding 8 permits for discharge, within the susceptible area (table 2).

Table 2. Contaminant source inventory.

Site Name	Identification Number	Reason for Permit	Reason for Listing as Potential Contaminant Source
DAVISON OIL AND GAS BURTON STA 7	MI0000540310	On-Site Storage	Hazardous and Solid Waste Site
H AND M SVC	MID985612225		
KINNIES PARTY STORE	MID985597657		
ZACK CO	MID002975225		
EVERGREEN CLEANERS	MID981539711		
DORT HWY INC	MID985579945		
SUPER GO MARKETERS INC	MID985583053		
PIONEER CABINETRY INC	MID985605849		
DAVISON CITY OF	MID985625136		
MID MICHIGAN AUTO PARTS INC	MID985654789		
CLARK STORE 1849	MI0001853613	Process, Treatment, and Waste Waters	Industrial Facilities Discharge Site
FORD-NORTHVILLE PLT	MI0024643		
FOREST WASTE PRODUCTS	YCRCLA276		
OTISVILLE WWTP ^a	MI0028720	Waste Water, Dust, and Process Water	Permit Compliance System
ORCHARD COVE WWTP	MI0054755		
OTISVILLE WWTP ^a	MI0028720		

Note: Subscript denotes multiple permits

Sensitivity Analysis

Sensitivity is the natural ability of a SWA to provide protection against the contamination of the water supply intake, and includes physical attributes of lakes, rivers, and soils. The sensitivity analysis requires consideration of several different variables related to the natural environment, for example:

- Water quality history of the source.
- Distribution of moderately to highly-permeable soils.
- Amount of available water from precipitation or runoff.
- Potential for runoff to affect the intake.
- Nature of the intake, including: depth, distance from shore, age, and materials used.
- Surface water flow patterns in vicinity of intake.

To perform this analysis, USGS, MDEQ, and the operator of the Flint WTP collected, researched, and analyzed information from the WTP, monthly operator reports, sanitary surveys, soil maps, published reports, and historical plant operation and raw water quality data. The Michigan SWAP has three categories of sensitivity for surface water sources ranging from moderately sensitive to very highly sensitive. Analysis of this information, using guidelines provided in Brogren (1999) and Sweat and others (2000, in press), indicates that the Flint intake is at the high end of this range or very highly sensitive (fig. 3). This means that the natural environment offers little protection against contamination of the water supply intake.

Susceptibility Determination

Susceptibility is the relative potential for contamination to reach the public water supply intake used for drinking water purposes. Whereas the sensitivity of a water supply is the natural ability of the area to protect the intake against contamination, the susceptibility determination also takes into account other factors that will affect whether a contaminant reaches the intake. Whether or not a particular drinking water source becomes contaminated depends on three factors:

- (1) The distribution of PCS;
- (2) The source water area; and
- (3) The natural protection, or sensitivity, of the source.

In conducting a susceptibility determination, the part of the SWA that yields water to the water supply-system intake is identified by establishment of the susceptible area within the source water area. PCS within the susceptible area are then located. Based on the distribution of PCS within the susceptible area, the type of PCS, and the nature of the chemicals they use or store, PCS are analyzed for the risk they may represent to the water supply intake. Along with the presence and distribution of PCS, the sensitivity analysis is then used to determine the susceptibility of the water supply (fig. 3). This leads to a determination of whether the drinking water source is moderately susceptible, highly susceptible, or very highly susceptible to contamination (Brogren, 1999; Sweat and others, in press). It is important to understand that a system can have low sensitivity relative to some conditions (for example, intake construction and location), and high susceptibility because of other conditions (for example, the type of PCS). In Michigan, surface water sources of drinking water range from moderately-low to very-high susceptibility.

When a public water supply is determined to have a moderate, high, or very high susceptibility because of a particular condition or set of conditions, there is a significant risk of contamination of the drinking water source because of that condition or set of conditions. Although the susceptibility determination does not predict when or if contamination will actually occur, it does recognize conditions that are highly favorable for contamination of the supply. In the event of a contaminant release to soils or surface water within the susceptible area, it is very likely that contamination at the intake would occur without completion of remedial actions.

If a public water supply's drinking water source is determined to be highly susceptible, it is recommended that the system identify the condition(s) that lead to the high susceptibility. Immediate steps should be taken to protect the source, and action should be considered to remedy the condition (for example, repairing or replacing faulty intake construction, working directly with facility operators to implement sound management practices, etc.).

All water supplies, regardless of their susceptibility, should consider identified factors that could lead to higher susceptibility in the future, and should prepare a strategy to protect the water supply source. Raising public awareness through signs and other education programs, encouraging proper intake construction and the use of best management practices in existing facilities are good ways of ensuring that a surface water source maintains its moderate susceptibility rating.

Summary and Recommendations

The actual susceptibility of the drinking water source of a water supply depends on a number of contributing factors, some of which are only slightly related. Sensitivity is determined from the natural setting of the source and identifies the natural protection afforded to the source water. Susceptibility is determined by identifying those factors within the community's SWA that may pose a risk to the source water. The susceptibility determination provides information with respect to facilities within the SWA or

land areas within the SWA that should be given greater priority and oversight in the implementation of a drinking water protection program.

Sensitivity Analysis: Based on criteria adopted in the Great Lakes Protocol of the Michigan Source Water Assessment Program, the emergency intake for the Flint Water Treatment Plant has a very high degree of sensitivity to potential contaminants.

Susceptibility Determination: The SWA for the Flint intake includes 8 listed potential contaminant sources within the susceptible area, numerous storm drains discharging upstream of the intake, a railroad crossing plus urban, agricultural, and industrial runoff from the Flint River watershed. Combining these potential contaminant sources with the very highly sensitive intake yields a very highly susceptible determination for Flint source water (fig. 5).

Effective Treatment:

The results of this assessment and the recommendations based on these results are summarized as follows:

- ***Intake*** - The Flint Water WTP intake was installed in 1948 and draws water from the Flint River from a shoreline structure making the intake very highly sensitive.
- ***Soils*** - Using a mean, area-weighted, depth-integrated permeability estimation, the soil and subsoil permeability in the SWA range from 0.6 in/hr to as much as 7.7 in/hr. The mean permeability is 3.1 in/hr (Schneider and Erickson, undated, series of 5 maps; BASINS, 1998; MIRIS, 2000). About two thirds of the soils in the Flint SWA are moderately rapid or rapidly permeable. Sixteen (16) PCS are located on these soils. These factors combine to make the SWA, and thus the intake, very highly sensitive. The community should take steps to evaluate current and future land use in areas of highly permeable soils, particularly those occurring within the susceptible area. Those PCS that have been identified either on or in close proximity to these soils should be informed of the sensitive nature of the area and encouraged to adopt best management practices designed to minimize the risk of a ground release. Residential areas that have been developed on these soils should be targeted for educational programs identifying steps that residents can take to protect the water supply.
- ***Historical Contaminant Detections*** - Since the Flint WTP has not utilized the Flint River since 1967 as a source of public drinking water, extensive raw water quality data is not available. However, as is typical for river water, the periodic presence of coliform bacteria is indicative of a relationship between runoff and soil conditions, causing the presence of bacteria at detectable levels in river source water. Background turbidity has recently been reported in the range of 2.4 to 7.6 NTU. These factors indicate that the SWA, and thus the intake, is very highly susceptible.
- ***Sanitary Survey*** - Defects reported as requiring repair either have been corrected or are scheduled for repair. The Flint WTP is undergoing extensive upgrades to improve treatment and reliability. It is important that the water supply continue to follow good management practices.
- ***Potential Contaminant Sources*** - A review of the PCS inventory and the rapidly and very rapidly permeable soil distribution indicates that the Flint SWA has 21 PCS located on moderately rapid to rapidly permeable soils. Within the susceptible area, there are 7 PCS with 8 discharge permits. In addition, there are numerous storm drains within the vicinity of the intake. A railroad crossing immediately upstream of the intake also poses a potential contaminant threat. It is recommended that the community focus initially on PCS that are within the susceptible area as they pose the greatest potential threat to the water supply. These facilities should be made aware of free technical assistance that is available through MDEQ's pollution prevention programs. Through chemical inventory, waste reduction, and by increasing awareness of best management practices, the risk these facilities pose to source waters can be reduced. The PCS inventory indicates that the source is very highly susceptible.
- ***Source Water Assessment*** - The Flint source water assessment is based on these site-specific parameters:

1. Definition of a Critical Assessment Zone around both intake for a very highly sensitive source;
 2. Definition of a SWA for the Flint River, and shoreline near the intake;
 3. Flow duration and discharge in the Flint River upstream of the intake, and the effects of upstream contaminant discharges on the source water quality; and
 4. Listed and nonlisted potential contaminant sources.
- **Source Water Protection** - The City has initiated source water protection activities with an Industrial Pretreatment Program incorporating management plans, chemical containment, and spill response, spill response training, plus storm sewer and street cleaning programs.

The Flint WTP and/or the community should assemble a team to assist in the development and implementation of a source water protection program that uses this assessment to further protect the Flint source water area.

Selected References

Blumer, S.P., Behrendt, T.E., Ellis, J.M., Minnerick, R.J., LeuVoy, R.L., and Whited, C.R., 2000, Water Resources Data Michigan Water Year 1999: Water-Data Report MI-99-1, 365 p.

Carpenter, S.R., Caraco, N.F., Correll, D.L., Howarth, R.W., Sharpley, A.N., and Smith, V.H., 1998, Nonpoint Pollution of Surface Waters with Phosphorus and Nitrogen, *Ecological Applications*, 8:3, 559-568.

City of Flint, 2002. About Flint. Statistical Snapshot. <http://www.cityofflint.com/About/stats.asp>. Accessed Feb 12, 2003.

Flint River Watershed Reports, Genesee County Health Department, April 15, 1999

Leonardi, J.M. and Gruhn, W.J., Flint River Assessment, Michigan DNR, July 2001

Lusch, D.P., Rader, C.P., Barrett, L.R., and Rader, N.K., 1992, Aquifer vulnerability to surface contamination in Michigan: Center for Remote Sensing and Department of Geography, Michigan State University, East Lansing, MI, scale 1:1,500,000.

Martin, H.M., 1955, Map of the surface formations of the southern peninsula of Michigan: Michigan Geological Survey, Department of Conservation, Publication 49, scale 1:500,000, 2 sheets.

Michigan Department of Environmental Quality, 2002. Clean Water Act Section 303(d) List Michigan Submittal for 2002. Staff Report. Draft. Surface Water Quality Division.

-----, 1999, State of Michigan Source Water Assessment Program, 153 p.

Miller, J.B. and Twenter, F.R., 1986, Michigan surface-water resources, in U.S. Geological Survey, National Water Summary 1985-hydrologic events and surface-water resources: U.S. Geological Survey Water-Supply Paper 2300, p. 277-284.

Milstein, R.L., compiler, 1987, Michigan sesquicentennial, 1837-1987, bedrock geology of southern Michigan: Michigan Department of Natural Resources, Geological Survey Division, scale 1:500,000.

MIRIS, 2000, Michigan Resource Information System: Michigan Department of Natural Resources, Land and Water Management Division, 2 compact discs, as updated.

National Oceanic and Atmospheric Administration, 1999, Climatological Data, Michigan: U.S. Department of Commerce, 113:13.

Rheume, S.J., 1991, Hydrologic provinces of Michigan: U.S. Geological Survey Water-Resources Investigation Report 91-4120, 73 p., 1 plate, scale 1:500,000.

Sweat, M.J., Erickson, P.M., and Brogren, B.B., 2000, The Michigan Source Water Assessment Program for Evaluation of Public Surface Water Supplies, in Bryant, Jeff, ed., NWQMC National Monitoring Conference 2000: Monitoring for the Millennium, Austin, TX, April 25-27, 2000.

Sweat, M.J., Brogren, B.B., Jodoin, R.S., Rossi, T.A., and Loerop, M.A., 2002, Michigan's Source Water Assessment Program -- Surface Water Assessments Leading to Protection Initiatives, in, Proceedings of

Watershed 2002: Water Environment Federation International Conference, February 23-27, 2002, Fort Lauderdale, FL, 28 p. (also MDEQ Source Water Assessment Report 22)

Sweat, M.J., Brogren, B.B., Jodoin, R.S., and Rossi, T.A., in press, A source water assessment program for evaluation of public water supplies using surface water sources in Michigan: U.S. Geological Survey Water Resources Investigations Report 01-xxxx, xx p (also MDEQ Source Water Assessment Report 8)

Twenter, F.R., Knutilla, R.L., and Nowlin, J.O., 1976, Water resources of Washtenaw County, Michigan: Washtenaw County Planning Commission, 143 p., 43 figs., 18 tables.

U.S. Department of Agriculture, in press, Soil survey of Washtenaw County, Michigan:

-----, 1982, Soil survey of Oakland County, Michigan: 167 p., 135 sheets.

-----, 1992, Soil survey of Ingham County, Michigan: 149 p., 84 sheets.

-----, 1993, Soil survey of Livingston County, Michigan: 92 p., 44 sheets.

-----, in press, Soil survey of Jackson County, Michigan:

GLOSSARY

Critical Assessment Zone (CAZ) - the area from the intake structure to the shoreline and inland, including a triangular water surface and a land area encompassed by an arc from the endpoint of the shoreline distance on either side of the on shore intake pipe location

Geographic Information System (GIS) - a system to capture, store, update, manipulate, analyze, and display all forms of geographically referenced information

Impaired water bodies - As defined by USEPA and listed on the 303 (d) list of the federal Clean Water Act.

Intake - the point at which source (raw) water is drawn into a pipe to be delivered to a water treatment plant

Lignins - an amorphous, cellulose-like, organic substance that acts as a binder for the cellulose fibers in wood and adds strength and stiffness to cell walls

Maximum Contaminant Level (MCL) - the maximum permissible level of a contaminant in water that is delivered to any user of a public water system

Potential Contaminant Sources (PCS) - listed and non-listed agricultural sites, businesses, and industries that have the potential to cause contaminants to be introduced into source water

Sensitivity - a measure of the physical attributes of the source area and how readily they protect the intake from contaminants

Source - the water body from which a water supplier gets its water

Source Water Area (SWA) - the land and water area upstream of an intake that has the potential to directly influence the quality of the water at the intake

Source Water Assessment Program (SWAP)- in Michigan, the process defined by the state Department of Environmental Quality to complete assessments of all the state's public water supplies

Susceptibility - the Susceptibility identifies factors that may pose a risk within the community's SWA

Susceptible Area - the area defined by the critical assessment zone and a buffer on either side of any drainages that contribute water to an intake

Synthetic Organic Contaminants (SOC) - Manmade organic chemical compounds such as pesticides, etc.

Tannins - naturally occurring phenolic compounds that precipitate proteins, alkaloids, and glucosides from solution that has a yellowish appearance

Volatile Organic Contaminants (VOC) - Unnatural, volatile organic chemical compounds such as gasoline components, solvents, degreasers, etc