
From: Busch, Stephen (DEQ)
Sent: Tuesday, September 09, 2014 3:21 PM
To: Shekter Smith, Liane (DEQ); Sygo, Jim (DEQ); Wurfel, Brad (DEQ)
Cc: Shaler, Karen (DEQ); Feuerstein, Heather (DEQ); Willard, Veronica (DEQ); Benzie, Richard (DEQ)
Subject: RE: Flint Site 5 Boil water advisory documents

FYI. The Boil water advisory in Flint has been lifted based on non-detect total coliform sample results.

I have spoken to Director Wyant and he is in contact with the Governor's office.

The City is continuing to investigate this area of its distribution system for possible sources of contamination.

Stephen Busch, P.E.
 Lansing and Jackson District Supervisor
 Office of Drinking Water and Municipal Assistance
 MDEQ
 517-643-2314

From: Shekter Smith, Liane (DEQ)
Sent: Friday, September 05, 2014 2:52 PM
To: Sygo, Jim (DEQ); Wurfel, Brad (DEQ)
Cc: Shaler, Karen (DEQ); Feuerstein, Heather (DEQ); Willard, Veronica (DEQ); Benzie, Richard (DEQ); Busch, Stephen (DEQ)
Subject: FW: Flint Site 5 Boil water advisory documents

FYI – heads up.

From: Busch, Stephen (DEQ)
Sent: Friday, September 05, 2014 2:47 PM
To: Daugherty Johnson (djohnson@cityofflint.com); Brent Wright (bwright@cityofflint.com); mglasgow@cityofflint.com
Cc: Benzie, Richard (DEQ); Shekter Smith, Liane (DEQ); Prysby, Mike (DEQ); Rosenthal, Adam (DEQ)
Subject: Flint Site 5 Boil water advisory documents

Gentlemen,

Attached are the boil water advisory public notice with all required language and a map of the impacted zone. Please distribute to your media contacts immediately.

Once we have 2 sets of non-detect samples from the impacted area we can discuss lifting the advisory.

You indicated that flushing of the area has already started.

Please ensure the water system is taking investigative steps to identify a possible source

- Inspect storage facilities
- Verify pumping and treatment system remains intact and uncontaminated
- Inspect cross connection accounts in the affected area
- Survey the area for any unidentified cross connections
- Review any recent construction or maintenance in the area

- Check for building permits and with building inspectors for any recent construction in the area
- Check with fire departments and DPW for any temporary or improper hydrant use
- Review pumpage and check for breaks, leaks, or an uptick in unaccounted water loss
- Ensure any vacant properties have had the water service shutoff
- Review CI residual data, conduct additional CI monitoring, and increase disinfectant residual

I will be in contact with the County Health Department and the MDARD Food and Dairy Division.

You can reach me over the weekend at this number or Mike Prysby at his number.

Stephen Busch, P.E.
Lansing and Jackson District Supervisor
Office of Drinking Water and Municipal Assistance
MDEQ
517-643-2314