

From: [Dykema, Linda D. \(DHHS\)](#)
To: [Shekter Smith, Liane \(DEQ\)](#); [Groetsch, Kory J. \(DHHS\)](#)
Cc: [Krisztian, George \(DEQ\)](#); [DeBruyn, Dana \(DEQ\)](#); [Busch, Stephen \(DEQ\)](#); [Devereaux, Tracy Jo \(DEQ\)](#); [Besey, Kevin \(MDARD\)](#)
Subject: RE: DRAFT DELIBERATIVE. NOT SUBJECT TO FOIA - Draft recommendations for restaurants from MDARD
Date: Wednesday, October 14, 2015 10:18:49 AM
Importance: High

We've seen a more finished version. I agree with the recommendations with some caveats:

- Can businesses get the free water testing offered to citizens?
- Some of the literature we've reviewed suggests that lines might need to be flushed if not used for less than 6 hours. School drinking fountains for example might need flushing at mid-day even if flushed in the morning.
- Can we be sure "bagged ice" was not produced locally?
- The sentence "Other equipment that may use city water:" could be read as permissive. Suggest changing may to "might be connected to."

From: Shekter Smith, Liane (DEQ)
Sent: Tuesday, October 13, 2015 2:07 PM
To: Dykema, Linda D. (DHHS); Groetsch, Kory J. (DHHS)
Cc: Krisztian, George (DEQ); DeBruyn, Dana (DEQ); Busch, Stephen (DEQ); Devereaux, Tracy Jo (DEQ); Besey, Kevin (MDARD)
Subject: DRAFT DELIBERATIVE. NOT SUBJECT TO FOIA - Draft recommendations for restaurants from MDARD
Importance: High

Linda and Kory –

The attached document was created by MDARD and modified by DEQ NCWS staff. MDARD plans to e-mail this to food establishments in the flint area and also provide it to the Genesee County LHD for their use. MDARD is anxious to get this out to restaurants but would like your review/comments prior to finalizing.

This is a request for content review. They'll take care of making it look nice.

Comments can go back to MDARD directly (Kevin Besey), but I'd like to be cc'd also so that we can see your comments also. That will help us craft future messages.

Thanks.