

From: [Busch, Stephen \(DEQ\)](#)
To: [Benzie, Richard \(DEQ\)](#); [Shekter Smith, Liane \(DEQ\)](#)
Cc: [Prysby, Mike \(DEQ\)](#); [Rosenthal, Adam \(DEQ\)](#)
Subject: Preliminary Flint TTHM results
Date: Friday, August 28, 2015 11:12:45 AM
Attachments: [3rd Qtr 2015 TTHM preliminary.doc](#)

Richard and Liane,

A PRELIMINARY Flint TTHM compliance determination is attached. (The one month monitoring window doesn't officially end until Monday 8/31).

Note all 8 sites would now be in compliance with the LRAA, but we did have one sample this quarter over 80 ppb (site 7, 90.3 ppb). This will make messaging a little more difficult.

Shall we proceed, after August 31, to create a "TTHM return to compliance" letter?

Stephen Busch, P.E.
MDEQ Lansing District Coordinator
Office of Drinking Water and Municipal Assistance
Lansing and Jackson District Supervisor
517-643-2314
buschs@michigan.gov