
From: Pieper, Julia (DEQ)
Sent: Sunday, October 04, 2015 2:03 PM
To: Shane, Kirby (DEQ);Krisztian, George (DEQ)
Subject: Re: Flint Schools Samples

The samples from Genesee county arrived Saturday morning and should be ready to run on Monday. I will expedite the data coding and proofing. Should these also be logged in as "Flint_Lead_Testing" rather than "Customer"?

Julia Pieper
Drinking Water Coordinator
Organic Sub-Unit Manager
DEQ-RD Laboratory Services
517-335-8076
pieperj2@michigan.gov

From: Shane, Kirby (DEQ)
Sent: Saturday, October 3, 2015 10:31 AM
To: Krisztian, George (DEQ)
Cc: Pieper, Julia (DEQ)
Subject: Flint Schools Samples

George – Testing is complete for samples LF86003 – LF86025, LF86027 – LF86039. One sample LF86026 requires a digestion that will be done Monday. Completed results have been validated in LIMS. The following four samples had lead concentrations above 0.015mg/L.

LF86004 – 0.031mg/L
LF86027 – 0.016mg/L
LF86037 – 0.028mg/L
LF86038 – 0.101mg/L

Kirby Shane
Chief, Inorganic Unit
Laboratory Services
MichiganDEQ
shane.k@michigan.gov
517.335.9888