

Olszewski, Rosemarie (DEQ)

From: Thelen, Mary Beth (DEQ)
Sent: Sunday, September 13, 2015 11:07 AM
To: Olszewski, Rosemarie (DEQ)
Subject: Wednesday Morning - Confidential Communications to Print for Possible FOIA.
Attachments: DWSD-CorrosionControlStudy.pdf; Flint lead history.pdf; DWSD-Flint-1993-Lead-Letter.pdf

More for Wednesday Morning.

From: Thelen, Mary Beth (DEQ)
Sent: Sunday, September 13, 2015 11:04 AM
To: Thelen, Mary Beth (DEQ)
Subject: FW: Need upate on lead / copper tests for Flint

Print for possible FOIA. Confidential Communications.

From: Wyant, Dan (DEQ)
Sent: Sunday, July 26, 2015 12:35 PM
To: Hollins, Harvey (GOV)
Subject: FW: Need upate on lead / copper tests for Flint

Harvey,

FYI, I will call you on Monday to discuss.

Dan Wyant, Director
 Department of Environmental Quality
 517-284-6700 (New Number)

From: Wurfel, Brad (DEQ)
Sent: Friday, July 24, 2015 4:18 PM
To: Saxton, Thomas (Treasury); Muchmore, Dennis (GOV); Wyant, Dan (DEQ)
Subject: FW: Need upate on lead / copper tests for Flint

Guys, here's an update and some clarification on the lead situation in Flint. Please limit this information to internal for now.

By the tenants of the federal statute, the city is in compliance for lead and copper. That aside, they have not optimized their water treatment (for the most part, this means adding phosphates to minimize the degree that the water Ph mobilizes lead and copper in people's home plumbing).

Compliance with the standard started with testing. A June-December run of tests (all in homes with lead in their premise plumbing) concluded in December. Another January – June round of sampling concluded last month. Everything checks out in terms of compliance, but now the next step is optimizing the water supply.

So, in about two weeks, DEQ will be sending a formal communication about the optimizing issue. The federal program has long timelines for action. A community water supplier gets 18 months to study the options, and two years thereafter to implement water system optimization measures.

My point: Conceivably, by the time we're halfway through the first timeline, the city will begin using a new water source with KWA ... and conceivably, the whole process starts all over again.

In terms of near-future issues, the bottom line is that residents of Flint do not need to worry about lead in their water supply, and DEQ's recent sampling does not indicate an eminent health threat from lead or copper. That said, anyone with lead pipes in their premise plumbing (this translates to tens of thousands of homes in our older urban centers, btw) should at least be aware that they have them, and to some limited degree that's going to impart minute parts per billion of lead in water no matter what. Its why nobody uses lead water pipes anymore.

The long version of this note is below. Let's connect next week. I'd like some thoughts about what more the state could be doing – most immediately, to convey the results of our testing and tell the story to the residents of Flint in an effort to quell some fears.

Thanks!

b

From: Busch, Stephen (DEQ)

Sent: Friday, July 24, 2015 3:46 PM

To: Wurfel, Brad (DEQ)

Cc: Shekter Smith, Liane (DEQ); Wyant, Dan (DEQ); Pallone, Maggie (DEQ); Prysby, Mike (DEQ); Benzle, Richard (DEQ)

Subject: RE: Need update on lead / copper tests for Flint

Brad,

As we discussed, the City has completed the last round of monitoring (Jan 1 – June 30, 2015). The last samples came in about a week ago. We have made the compliance determination that the 90th percentile level is 11 parts per billion, which is below the Action Level Standard of 15 parts per billion (there is no Lead maximum contaminant level standard). The federal rule requires measuring lead levels in water from household plumbing materials to determine the corrosivity of the City's water in order to limit exposure.

I have provided a summary of Flint's lead compliance monitoring from the last 20+ years since this regulation started in 1991. The City of Flint itself has never had a 90th percentile level exceed the 15 part per billion action level. Sampling requirements look at the worst case plumbing materials. Samples must be collected in accordance with the regulatory requirements and criteria in order to be used for compliance determinations.

Because the City of Flint serves a population of over 50,000 they are required to have Fully Optimized Corrosion Control. While it is possible to meet the fully optimized requirement without additional treatment, based on their two rounds of sampling since switching to the Flint River, we have determined they did not meet the eligibility for this per the regulation. They now have to complete a study (within 18 months) and are then allowed a period of additional time (2 additional years) to install the selected treatment for Fully Optimized Corrosion Control in accordance with the regulatory requirements. This is what DWSD was required to do back in 1993 – 1997 (see attached letter and study). We are planning to suggest the City directly submit a treatment process to shorten the timeline to achieve full optimization. This letter is currently being drafted but won't be ready to mail out for another week.