

Rennaker, Joanne (DEQ)

From: Michael Glasgow <mglasgow@cityofflint.com>
Sent: Thursday, January 29, 2015 2:15 PM
To: Prysby, Mike (DEQ)
Subject: Flint December 2014 MOR
Attachments: Dec 2014 MOR Scan.pdf

Mike,

Good afternoon, I hope all is well there in Lansing. I just wanted to send a copy of the December MOR to you. I thought it was taken care of while I was off, sorry for the delay. A hard copy will go out tomorrow.

Mike Glasgow
City of Flint Water Plant

CITY of FLINT WATER TREATMENT PLANT MONTHLY OPERATION REPORT

SUPPLY NAME: CITY of FLINT WATER PLANTWSSN: 2310Michael Glasgow

Operator-in-Charge

December 2014

Month/Year

F-1R, F-2

Certification of Operator-in-Charge

F-1

Water Plant Classification

Michael Glasgow

Signature of Operator-in-Charge

Genesee

County

Treatment Rate and Filter Data

Maximum Treatment Rate:	<u>23.8</u>	Million Gallons per Day
Rated Plant Capacity:	<u>36</u>	Million Gallons per Day
Average Filter Run:	<u>74</u>	Hours
Average Head Loss:	<u>n/a</u>	Feet *(filter head loss meters not operational)
Average Filtration Rate:	<u>2.4</u>	Gallons Per Square Feet per Minute
Maximum Filtration Rate:	<u>3.2</u>	Gallons Per Square Feet per Minute
Average Wash Water Use:	<u>2.9%</u>	Percent of Treated Water

Chemical Data

Chlorine on hand:	<u>20,000</u> lb.	Est. supply:	<u>30</u> days
Primary Coagulant (Ferric Chloride) on hand:	<u>54,000</u> lb.	Est. supply:	<u>18</u> days
Lime (CaO) on hand:	<u>298</u> tons	Est. supply:	<u>34</u> days
Fluoride on Hand:	<u>16,630</u> lb.	Est. supply:	<u>35</u> days
Cost of All Chemicals per Million Gallons:	<u>n/a</u> dollars		
Total Power Cost per Million Gallons:	<u>n/a</u> dollars		

Remarks

Confluence Point # 1 (N)

Confluence Point # 2 (S)

Number of filter confluence samples > 0.3 NTU:

00

Number of filter confluence samples collected:

226226

Percent of filter confluence samples > 0.3 NTU:

0.0%0.0%

Number of filter confluence samples > 1 NTU

00

Did any individual filter exceed:

1.0 NTU in two consecutive measurements taken 15 minutes apart?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

0.5 NTU in two consecutive measurements taken 15 minutes apart after 4 hours of operation?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

1.0 NTU in two consecutive measurements taken 15 minutes apart for 3 consecutive months?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

2.0 NTU in two consecutive measurements taken 15 minutes apart for 2 consecutive months?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

Was continuous (every 15 minutes) filter monitoring equipment off-line during the month?

NO

If yes, indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet.

Did POE disinfectant residual fall below 0.2 ppm during the month?

NO

If yes, indicate date(s) and duration on a separate sheet.

Was minimum C^{*}I credit achieved for the entire month?YES

If no, indicate on a separate sheet the date(s) not achieved.

Was continuous POE chlorine residual monitoring equipment off-line during the month?

NO

If yes, indicate date(s) and duration on a separate sheet.