

Rennaker, Joanne (DEQ)

From: Howard Croft <hcroft@cityofflint.com>
Sent: Thursday, March 12, 2015 10:53 AM
To: Brent Wright; Daugherty Johnson; Dayne Walling; donna. cole; gdn2@aol.com; Howard Croft; James Henry; jmikewright; JoAnne Herman; John O'Brien; Kirk Smith; larry.koehler@mcc.edu; Laura Sullivan; Michael Glasgow; Mike Lane; Prysby, Mike (DEQ); Natasha Henderson; Norb Birchmeier; Pete Levine; rob.nicholas@veolia.com; Robert Nicholas; rosejo@msu.edu; Russell Hudson; Samir Matta; Warren Green
Subject: Water Update

All,

We still have not received the violation notice from the DEQ although we expect it any day now. We continue to work on what additional documentation will accompany the letter and still plan to vet that through this group. We would like to have the notice in hand to verify how it reads before completing our draft copy of accompanying documents.

We are planing to have another community advisory group meeting next Thursday March 19th. I will wait to set the next **Technical Advisory Meeting** date and agenda until after that group meets.

Thank you,

--

Howard Croft
 Public Works Director
 City of Flint
 1101 S. Saginaw Street
 Flint, MI 48502
 PH# 810.766.7135 Ext.2043
hcroft@cityofflint.com

Rennaker, Joanne (DEQ)

From: Busch, Stephen (DEQ)
Sent: Wednesday, March 11, 2015 9:19 AM
To: Prysby, Mike (DEQ)
Subject: RE: City of Flint February 2015 MOR

Follow Up Flag: Follow up
Flag Status: Flagged

I assume you are referring to the one confluence sample above 0.3 NTU. It would be a good idea to verify with the City their filter operation protocols. If they had the ability to filter to waste or move the filter(s) directly into backwash prior to hitting 0.3 that would have been preferable. It also be worth looking at the trending data for each filter to see if it was across the board or a particular filter and at what point it was at in the filter run cycle.

Stephen Busch, P.E.
 Lansing and Jackson District Supervisor
 Office of Drinking Water and Municipal Assistance
 MDEQ
 517-643-2314

From: Prysby, Mike (DEQ)
Sent: Tuesday, March 10, 2015 1:47 PM
To: Busch, Stephen (DEQ)
Subject: FW: City of Flint February 2015 MOR

Steve,

The cold water and high flows challenged the city's ability to maintain acceptable treatment. Although they met standards according to our rules, the high treatment rate later in the month and low water temp did have some impact.

Michael Prysby, P.E.
 District Engineer
 Office of Drinking Water and Municipal Assistance
 517 290-8817

From: Michael Glasgow [<mailto:mglasgow@cityofflint.com>]
Sent: Tuesday, March 10, 2015 9:46 AM
To: Prysby, Mike (DEQ)
Subject: City of Flint February 2015 MOR

Mike,

Good morning, I just wanted to get you a copy of the February MOR. A copy will go out in the mail today.