

From: [Shekter Smith, Liane \(DEQ\)](#)
 To: [DeBruyn, Dana \(DEQ\)](#)
 Cc: [Devereaux, Tracy Jo \(DEQ\)](#); [Krisztian, George \(DEQ\)](#); [Busch, Stephen \(DEQ\)](#)
 Subject: RE: Info from potter
 Date: Friday, December 04, 2015 11:28:00 AM

Is the piping really close together in some locations or do they suspect a possible cross connection?

-----Original Message-----

From: DeBruyn, Dana (DEQ)
 Sent: Friday, December 04, 2015 11:27 AM
 To: Shekter Smith, Liane (DEQ)
 Cc: Devereaux, Tracy Jo (DEQ); Krisztian, George (DEQ); Busch, Stephen (DEQ)
 Subject: Re: Info from potter

To document how extremely hot some of the water is after over 5 minutes of flushing. To give it a number and not just a warm or hot description would be my suggestion. Joe and others are unsure why some are so hot and others not.

Also some have first draw cold room temp and then turn to hot.

Sent from my iPhone

> On Dec 4, 2015, at 10:39 AM, Shekter Smith, Liane (DEQ) <SHEKTERL@michigan.gov> wrote:

>

> Dana - I'm missing the point. What's the benefit/purpose of having a thermometer?

>

>

>

>

> -----Original Message-----

> From: DeBruyn, Dana (DEQ)
 > Sent: Friday, December 04, 2015 10:30 AM
 > To: Devereaux, Tracy Jo (DEQ)
 > Cc: Shekter Smith, Liane (DEQ)
 > Subject: Re: Info from potter

>

> I would suggest someone pick up a NSF food grade thermometer for tomorrow. Maybe borrow one from MDARD food and dairy.

>

> Sent from my iPhone

>

>> On Dec 4, 2015, at 9:00 AM, Devereaux, Tracy Jo (DEQ) <DEVEREAUXT@michigan.gov> wrote:

>>

>> Done, thanks Dana.

>>

>> Thanks,

>> Tracy Jo

>>

>>

>> -----Original Message-----

>> From: DeBruyn, Dana (DEQ)
 >> Sent: Friday, December 04, 2015 8:59 AM
 >> To: Devereaux, Tracy Jo (DEQ)

>> Cc: Shekter Smith, Liane (DEQ)

>> Subject: Info from potter

>>

>> So far Half of the rooms have hot water in the cold taps due to the boiler.

>> Please pass this along to George. His email is not coming up for me.

>> Dana

>>

>> Sent from my iPhone