

Rennaker, Joanne (DEQ)

From: Prysby, Mike (DEQ)
Sent: Tuesday, September 01, 2015 3:50 PM
To: Hansen, Jeff; 'bwright@cityofflint.com'; Michael Glasgow
Subject: RE: Flint OER - Response to May 2015 TTHM Sampling
Attachments: 3rd Qtr 2015 TTHM summary.doc

Jeff, Brent, Michael

Attached is DEQ's summary of TTHM concentrations for the past 4 quarters including the LRAA and OEL calculation. This table is aligned correctly between locations (addresses) and site codes and needs to be used by city.

Michael Prysby, P.E.
 District Engineer
 Office of Drinking Water and Municipal Assistance
 517 290-8817

From: Hansen, Jeff [<mailto:jrhansen@lan-inc.com>]
Sent: Tuesday, September 01, 2015 3:42 PM
To: Prysby, Mike (DEQ)
Cc: hcroft@cityofflint.com; mglasgow@cityofflint.com; Brent Wright (bwright@cityofflint.com); Robert Bincsik (rbincsik@cityofflint.com); Matta, Samir; Green, Warren; Luoma, Steve
Subject: Flint OER - Response to May 2015 TTHM Sampling

Hi Mike,

On behalf of the City of Flint, attached is a PDF version of the latest Operational Evaluation Report required in response to the TTHM violation in May 2015. Hard copies will be sent out today.

Jeffrey R. Hansen
 Senior Project Manager



**Lockwood, Andrews
& Newnam, Inc.**
 A FIDELITY & DAILY COMPANY

1311 South Linden Road, Suite B • Flint, MI 48532
 T 810.820.2682 C 810.333.3201
www.lan-inc.com • JRHansen@lan-inc.com

CONFIDENTIALITY AND PRIVILEGE NOTICE: This email communication, including any and all attachments, (collectively, this "Communication"), is intended solely for the person(s) to whom it is addressed. This Communication may contain information that is privileged, confidential and/or proprietary. Any unauthorized use, disclosure or copying of this Communication is strictly prohibited. If you have received this Communication in error, please contact the sender immediately and destroy any and all copies of this Communication.

02310 – City of Flint 3rd Quarter 2015 TTHMs

August 28, 2015

TTHM Results (mg/L)						
	11/20/14	2/17/15	5/18/15	8/18/15	LRAA	OEL
DBP1 McDonalds 3719 Davison	0.059	0.0162	0.0514	0.0755	0.050	0.055
DBP2 Liquor Palace 3302 South Dort Highway	0.033	0.0168	0.0635	0.0532	0.042	0.047
DBP3 North Flint Auto 6204 North Saginaw St.	0.041	0.0149	0.0452	0.0426	0.036	0.036
DBP4 University Market 2501 Flushing Road	0.094	0.0245	0.0598	0.0706	0.062	0.056
DBP5 Taco Bell 3606 Corunna Road	0.034	0.0151	0.0547	0.0619	0.042	0.049
DBP6 Rite-Aid Pharmacy 5018 Clio Road	0.054	0.0192	0.0605	0.0595	0.048	0.050
DBP7 Salem Housing 3216 MLK Boulevard	0.050	0.0285	0.0727	0.0903	0.060	0.070
DBP8 BP Gas Station 822 South Dort Highway	0.036	0.0199	0.0461	0.0549	0.039	0.044