

Rennaker, Joanne (DEQ)

From: Prysby, Mike (DEQ)
Sent: Monday, August 10, 2015 11:47 AM
To: Busch, Stephen (DEQ)
Subject: Flint pH
Attachments: Flint pH 2014-2015.doc

Steve,

Attached is a summary of WTP Ptap and Dist. pH values for Flint for the months of April, May, and June. I have not received the July MOR or the 2015 2nd Qtr WQP report from the city....

Michael Prysby, P.E.
District Engineer
Office of Drinking Water and Municipal Assistance
517 290-8817

**City of Flint
Water System pH**

WTP Plant Tap

April 2015 :	Avg: 7.83	Range: 7.54 - 8.02
May 2015:	Avg: 7.60	Range: 7.35 - 7.88
June 2015:	Avg: 7.61	Range: 7.40 - 7.76

WQ Parameter Sites:

25 locations: Routine bacteriological monitoring sites (8 locations) and the Westside and Cedar Street reservoirs. 15 additional sites throughout the city following expansion of the pb/cu monitoring program.

2014 - 3rd Qtr:	Avg: 7.71	Range: 7.56 – 7.86
2014 - 4th Qtr:	Avg: 7.88	Range: 7.62 – 8.10
2015 - 1st Qtr	Avg: 7.81	Range: 7.60 – 7.99