

Rennaker, Joanne (DEQ)

From: Michael Glasgow <mglasgow@cityofflint.com>
Sent: Friday, July 10, 2015 4:13 PM
To: Prysby, Mike (DEQ)
Subject: City of Flint MOR - June 2015
Attachments: June 2015 MOR.pdf

Mike,

Here is a copy of the June MOR. A hard copy was mailed out earlier today.

--

Mike Glasgow
Utilities Administrator
City of Flint
1101 S. Saginaw St.
Flint, MI 48502
(810)766-7135 ext. 2602

CITY of FLINT WATER TREATMENT PLANT MONTHLY OPERATION REPORT

SUPPLY NAME: CITY of FLINT WATER PLANT

WSSN: 2310

Michael Glasgow

Operator-in-Charge

June 2015

Month/Year

F-1R, F-2

Certification of Operator-in-Charge

F-1

Water Plant Classification

Michael Glasgow
Signature of Operator-in-ChargeGenesee

County

Treatment Rate and Filter Data

Maximum Treatment Rate:	<u>18.5</u>	Million Gallons per Day
Rated Plant Capacity:	<u>36</u>	Million Gallons per Day
Average Filter Run:	<u>90</u>	Hours
Average Head Loss:	<u>n/a</u>	Feet *(filter head loss meters not operational)
Average Filtration Rate:	<u>2.3</u>	Gallons Per Square Feet per Minute
Maximum Filtration Rate:	<u>3.3</u>	Gallons Per Square Feet per Minute
Average Wash Water Use:	<u>2.0%</u>	Percent of Treated Water

Chemical Data

Chlorine on hand:	<u>12,000</u> lb.	Est. supply:	<u>13</u> days
Primary Coagulant (Ferric Chloride) on hand:	<u>220,000</u> lb.	Est. supply:	<u>13</u> days
Lime (CaO) on hand:	<u>259</u> tons	Est. supply:	<u>32</u> days
Fluoride on Hand:	<u>18,000</u> lb.	Est. supply:	<u>45</u> days
Cost of All Chemicals per Million Gallons:	<u>n/a</u> dollars		
Total Power Cost per Million Gallons:	<u>n/a</u> dollars		

Remarks

Confluence Point # 1 (N)

Confluence Point # 2 (S)

Number of filter confluence samples > 0.3 NTU:

00

Number of filter confluence samples collected:

211211

Percent of filter confluence samples > 0.3 NTU:

0.0%0.0%

Number of filter confluence samples > 1 NTU

00

Did any individual filter exceed:

1.0 NTU in two consecutive measurements taken 15 minutes apart?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

0.5 NTU in two consecutive measurements taken 15 minutes apart after 4 hours of operation?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

1.0 NTU in two consecutive measurements taken 15 minutes apart for 3 consecutive months?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

2.0 NTU in two consecutive measurements taken 15 minutes apart for 2 consecutive months?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

Was continuous (every 15 minutes) filter monitoring equipment off-line during the month?

NO

If yes, indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet.

Did POE disinfectant residual fall below 0.2 ppm during the month?

NO

If yes, indicate date(s) and duration on a separate sheet.

Was minimum C*T credit achieved for the entire month?

YES

If no, indicate on a separate sheet the date(s) not achieved.

Was continuous POE chlorine residual monitoring equipment off-line during the month?

NO

If yes, indicate date(s) and duration on a separate sheet.