

Rennaker, Joanne (DEQ)

From: Busch, Stephen (DEQ)
Sent: Friday, February 27, 2015 2:02 PM
To: 'jr Hansen@lan-inc.com'
Subject: Updated TTHM results for Flint
Attachments: FLINT TTHM RESULTS.docx

Jeff,

See the attached table with updated February results, LRAA's, and OEL's.

Stephen Busch, P.E.
Lansing and Jackson District Supervisor
Office of Drinking Water and Municipal Assistance
MDEQ
517-643-2314

FLINT TTHM RESULTS

TTHM Results (mg/L)						
	5/21/14	8/21/14	11/20/14	2/17/15	LRAA	OEL
DBP1 McDonalds 3719 Davison	0.162	0.145	0.059	0.0162	0.096	0.059
DBP2 Liquor Palace 3302 S. Dort Highway	0.112	0.127	0.033	0.0168	0.072	0.049
DBP3 North Flint Auto 6204 N. Saginaw St.	0.097	0.118	0.041	0.0149	0.068	0.047
DBP4 University Market 2501 Flushing Road	0.106	0.196	0.094	0.0245	0.105	0.085
DBP5 Taco Bell 3606 Corunna Road	0.079	0.181	0.034	0.0151	0.078	0.063
DBP6 Rite-Aid Pharmacy 5018 Clio Road	0.088	0.144	0.054	0.0192	0.076	0.059
DBP7 Salem Housing 3216 MLK Boulevard	0.082	0.112	0.050	0.0285	0.068	0.055
DBP8 BP Gas Station 822 S. Dort Highway	0.075	0.112	0.036	0.0199	0.061	0.047