

6566-15
ODWMA-LDO
due: 9-23-15

DEQFOIA

To: Marc Edwards
Subject: RE: FOIA: 76 sample results for FLINT LCR. I would like to see the other 4-6 results.

From: Marc Edwards [<mailto:edwardsm@vt.edu>]
Sent: Monday, September 14, 2015 7:24 PM
To: DEQFOIA
Subject: FOIA: 76 sample results for FLINT LCR. I would like to see the other 4-6 results.

On July 9th, Mike Glasgow of Flint sent an e-mail saying he submitted more bottles, achieving 76 samples total for the LCR compliance.

I would like to see the results of analyzing the 4-6 additional samples, when they were collected, lead results, etc..

The initial report had 71 samples.

Thank you.

Marc Edwards
Virginia Tech
407 Durham Hall
Blacksburg, VA 24061

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003
P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562



**Sample Number
LF64282**

Official Laboratory Report

Report To: **MIKE GLASGOW
4500 N DORT HWY
FLINT MI 48505**

Baseline Not Taken

System Name/Owner:	CITY OF FLINT	WSSN/Pool ID:	2310
Collection Address:	625 S GRAND TRAVERSE, FLINT	Source:	TYPE III
Collected By:	MIKE GLASGOW	Site Code:	
Township/Well#/Section:	//	Collector:	Public Water Supply Operator
County:	Genesee	Date Collected:	05/15/2015 13:00
Sample Point:	BATHROOM	Date Received:	05/20/2015 11:24
Water System:	Treated Public Distribution System	Purpose:	Other

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Copper	0.14	05/21/2015	0.05	1.3	EPA 200.8	7440-50-8
Lead	0.017	05/21/2015	0.001	0.015	EPA 200.8	7439-92-1

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U. S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

**Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603**

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminant Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contacts
Drinking Water Unit Mgr: Julia Piepor
Systems Mgmt. Unit Mgr: George Krisztian