

Rennaker, Joanne (DEQ)

From: Rosenthal, Adam (DEQ)
Sent: Friday, April 10, 2015 12:04 PM
To: Busch, Stephen (DEQ)
Subject: FW: January 2015 MOR
Attachments: January 2015 MOR scan.pdf; January 2015 Bromate Results.pdf

Adam Rosenthal, EQA
MDEQ – Office of Drinking Water and Municipal Assistance
Lansing District – Constitution Hall 1SW
PO Box 30242
Lansing, MI 48909
517-284-6644
fax: 517-241-3571

For MORs, Lab Results & Reporting Forms:
DEQ-DWMA-Lansing@michigan.gov

From: Michael Glasgow [<mailto:mglasgow@cityofflint.com>]
Sent: Tuesday, February 10, 2015 3:56 PM
To: Prysby, Mike (DEQ); Rosenthal, Adam (DEQ)
Subject: January 2015 MOR

Mike & Adam,

Here is copy of the MOR for the month of January. Brent will be sending out a hard copy in the mail today. I have also included the January monthly bromate test results.

Mike Glasgow
City of Flint Water Plant

CITY of FLINT WATER TREATMENT PLANT MONTHLY OPERATION REPORT

SUPPLY NAME: CITY of FLINT WATER PLANTWSSN: 2310Michael Glasgow

Operator-in-Charge

January 2015


Month/Year

F-1R, F-2

Certification of Operator-in-Charge

F-1

Water Plant Classification



Signature of Operator-in-Charge

Genesee

County

Treatment Rate and Filter Data

Maximum Treatment Rate:	<u>19.3</u>	Million Gallons per Day
Rated Plant Capacity:	<u>36</u>	Million Gallons per Day
Average Filter Run:	<u>76</u>	Hours
Average Head Loss:	<u>n/a</u>	Feet *(filter head loss meters not operational)
Average Filtration Rate:	<u>2.1</u>	Gallons Per Square Feet per Minute
Maximum Filtration Rate:	<u>3.6</u>	Gallons Per Square Feet per Minute
Average Wash Water Use:	<u>3.2%</u>	Percent of Treated Water

Chemical Data

Chlorine on hand:	<u>12,000</u>	lb.	Est. supply:	<u>18</u>	days
Primary Coagulant (Ferric Chloride) on hand:	<u>110,000</u>	lb.	Est. supply:	<u>10</u>	days
Lime (CaO) on hand:	<u>257</u>	tons	Est. supply:	<u>22</u>	days
Fluoride on Hand:	<u>16,830</u>	lb.	Est. supply:	<u>42</u>	days
Cost of All Chemicals per Million Gallons:	<u>n/a</u>	dollars			
Total Power Cost per Million Gallons:	<u>n/a</u>	dollars			

Remarks

Confluence Point # 1 (N)

Confluence Point # 2 (S)

Number of filter confluence samples > 0.3 NTU:

00

Number of filter confluence samples collected:

244242

Percent of filter confluence samples > 0.3 NTU:

0.0%0.0%

Number of filter confluence samples > 1 NTU

00

Did any individual filter exceed:

1.0 NTU in two consecutive measurements taken 15 minutes apart?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

0.5 NTU in two consecutive measurements taken 15 minutes apart after 4 hours of operation?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

1.0 NTU in two consecutive measurements taken 15 minutes apart for 3 consecutive months?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

2.0 NTU in two consecutive measurements taken 15 minutes apart for 2 consecutive months?

NO

If yes, attach specific filter(s) information and indicate required follow-up status.

Was continuous (every 15 minutes) filter monitoring equipment off-line during the month?

NO

(If yes, indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet.

Did POE disinfectant residual fall below 0.2 ppm during the month?

NO

If yes, indicate date(s) and duration on a separate sheet.

Was minimum C*T credit achieved for the entire month?

YES

If no, indicate on a separate sheet the date(s) not achieved.

Was continuous POE chlorine residual monitoring equipment off-line during the month?

NO

If yes, indicate date(s) and duration on a separate sheet.