

Rennaker, Joanne (DEQ)

From: Busch, Stephen (DEQ)
Sent: Friday, July 11, 2014 12:01 PM
To: Prysby, Mike (DEQ); Rosenthal, Adam (DEQ)
Subject: RE: City of Flint June 2014 MOR

Let's try and troubleshoot distribution system operational modification recommendations on Monday. The treatment seems to be good. They are getting total chlorine residual in all distribution samples.

Stephen Busch, P.E.
 Lansing and Jackson District Supervisor
 Office of Drinking Water and Municipal Assistance
 MDEQ
 517-643-2314

From: Prysby, Mike (DEQ)
Sent: Friday, July 11, 2014 11:42 AM
To: Rosenthal, Adam (DEQ)
Cc: Busch, Stephen (DEQ)
Subject: FW: City of Flint June 2014 MOR

Adam,

Here's Flint's June 2014 MOR...as we discussed, the distribution system CL2 residual problem has worsened not to mention 2 positives (from their reservoirs). I will confirm with Brent as to whether they installed chlorination at the Westside/Cedar St. PSs for SDWIS updateas he indicated in my most recent site visit.

Michael Prysby, P.E.
 District Engineer
 Office of Drinking Water and Municipal Assistance
 517 290-8817

From: Michael Glasgow [<mailto:mglasgow@cityofflint.com>]
Sent: Thursday, July 10, 2014 3:11 PM
To: Prysby, Mike (DEQ)
Subject: City of Flint June 2014 MOR

Mike,

Good afternoon, I hope you had an enjoyable holiday weekend. Attached is a copy of our June 2014 MOR. There were a few alterations as per our discussion in early June. A copy is being sent out in the mail today. I just thought you might like a copy a few days before it arrives in the mail.

Mike Glasgow
 City of Flint Water Plant

