

Rennaker, Joanne (DEQ)

From: Michael Glasgow <mglasgow@cityofflint.com>
Sent: Tuesday, January 29, 2013 1:42 PM
To: Rosenthal, Adam (DEQ)
Subject: Re: Water Quality Parameters
Attachments: 3rdqtrWQM.xls; 4thqtrWQM.xls

Adam,

Attached are the 3rd & 4th Quarter Water Quality Monitoring Parameters. I have recently given Mr. Prysby a copy of our updated Sample Site Plan for approval. I will send you a copy also.

Mike Glasgow
City of Flint Water Plant

On Fri, Jan 25, 2013 at 3:02 PM, Rosenthal, Adam (DEQ) <ROSENTHALA@michigan.gov> wrote:

Ili Mike, I can't find copies of your 3rd or 4th quarter WQPs for 2012. Please email or fax copies when you get this.

thanks,

Adam Rosenthal, EQA

MDEQ – Office of Drinking Water & Municipal Assistance

Lansing District - 4th Floor North

PO Box 30242

Lansing, MI 48909

517-335-6131

fax: 517-241-3571



2012 3rd Quarter Water Quality Monitoring Results						
SAMPLE POINT IDENTIFICATION			PARAMETERS AND RESULTS			
Distribution System Location #	Sample Point Name & Address	Sample Date	Temperature (C)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Total Phosphorous (mg/L)
#1	Arby's 3742 Davison Rd.	9/5/2012	23.7	7.66	76	1.13
#2	BP Gas Station 822 S.Dort Hwy	9/5/2012	23.7	7.51	75	1.22
#3	7-11 3302 S. Dort Hwy	9/5/2012	21.5	7.50	76	1.21
#4	Taco Bell 3606 Corunna Rd.	9/5/2012	22.6	7.52	74	1.23
#5	7-11 2501 Flushing Rd.	9/5/2012	25.1	7.51	76	1.19
#6	Salem Housing 3216 MLK Blvd.	9/5/2012	25.5	7.58	75	1.25
#7	Rite-Aid 5018 Clio Rd.	9/5/2012	22.1	7.56	76	1.24
#8	N. Flint Automotive 6204 N. Saginaw St.	9/5/2012	24.7	7.56	74	1.31
CS	Cedar Street Reservoir & Pump Station	9/5/2012	21.4	7.49	76	1.26
WS	West Side Reservoir & Pump Station	9/5/2012	22.3	7.49	76	1.21