

Rennaker, Joanne (DEQ)

From: Michael Glasgow <mglasgow@cityofflint.com>
Sent: Thursday, August 30, 2012 8:23 AM
To: Rosenthal, Adam (DEQ)
Subject: Re: Water Quality Parameters
Attachments: 1stqtrWQM.xls

Adam,

Here is our 1st quarter water quality monitoring from this year. Sorry it took a couple days. I have been off for the last three days.

Mike Glasgow
Laboratory & Water Quality Supervisor
City of Flint - Water Plant
(810)787-6537

On Tue, Aug 28, 2012 at 2:41 PM, Rosenthal, Adam (DEQ) <ROSENTHALA@michigan.gov> wrote:

Hi Mike, looked all over and can't find your 1st quarter 2012 water quality parameters. Please fax or email a copy when you get this.

thanks,

Adam Rosenthal, EQA

MDEQ - RMD

Lansing District - 4th Floor North

PO Box 30242

Lansing, MI 48909

517-335-6131

fax: 517-241-3571



2012 1st Quarter Water Quality Monitoring Results						
SAMPLE POINT IDENTIFICATION			PARAMETERS AND RESULTS			
Distribution System Location #	Sample Point Name & Address	Sample Date	Temperature (C)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Total Phosphorous (mg/L)
#1	McDonalds Davison Rd.	2/28/2012	11.3	7.41	78	1.13
#2	BP Gas Station Dort Hwy	2/28/2012	7.7	7.43	75	1.22
#3	7-11 S. Dort Hwy	2/28/2012	9.7	7.37	77	1.18
#4	Taco Bell Ballenger Rd.	2/28/2012	6.9	7.38	77	1.31
#5	7-11 Flushing Rd.	3/1/2012	8.5	7.35	77	1.13
#6	Salem Housing MLK Blvd.	3/1/2012	10.6	7.39	75	1.16
#7	Rite-Aid Clio Rd.	3/1/2012	9.3	7.47	76	1.19
#8	N. Flint Automotive N. Saginaw St.	3/1/2012	12.2	7.36	76	1.20
CS	Cedar Street Reservoir & Pump Station	3/1/2012	9.1	7.38	77	1.23
WS	West Side Reservoir & Pump Station	3/1/2012	6.4	7.33	78	1.20