

From: [Shekter Smith, Liane \(DEQ\)](#)
To: [Prysby, Mike \(DEQ\)](#); [Busch, Stephen \(DEQ\)](#)
Subject: FW: Recommissioning the 72-inch transmission main
Date: Monday, October 19, 2015 5:18:00 PM

Mike – I'm not seeing a follow-up e-mail to George on this. Could you please respond? Thanks.

From: Krisztian, George (DEQ)
Sent: Thursday, October 15, 2015 10:38 AM
To: Prysby, Mike (DEQ)
Cc: Sygo, Jim (DEQ); Shekter Smith, Liane (DEQ)
Subject: RE: Recommissioning the 72-inch transmission main

Mike,

How is the flush water being disposed? Do we have an answer to that?

George

George L. Krisztian
Flint Action Plan Coordinator
Laboratory Director
Michigan Department of Environmental Quality
Desk ph (517) 284-6719
Cell ph (517) 204-0381

From: Prysby, Mike (DEQ)
Sent: Thursday, October 15, 2015 10:31 AM
To: Howard Croft (hcroft@cityofflint.com); Michael Glasgow; bwright@cityofflint.com; Tim Davidek (T_DAVIDEK@gdcwws.com); jfobrien@gdcwws.com; "mhorgan@gdcwws.com".GWIA.SOM-GWIA01; Krisztian, George (DEQ); Shekter Smith, Liane (DEQ); Busch, Stephen (DEQ); Benzie, Richard (DEQ); Rosenthal, Adam (DEQ)
Subject: Recommissioning the 72-inch transmission main

Based upon discussions with Genesee County and the city of Flint, the portion of the 72-inch transmission main (pipeline) that was taken out of service, while the Flint Water Treatment Plant (WTP) treated water from the Flint River, was flushed and disinfected in accordance to AWWA Standard C651-14. Two sets of samples were collected from two locations 16 hours apart for total coliform analysis. The city of Flint and Genesee County has informed the DEQ that both sets of samples are Non-Detect for total coliform. Based upon the disinfection procedure and the absence of total coliform from both sets of samples, the unused portion of the pipeline may be placed into service.

Michael Prysby, P.E.

District Engineer

Office of Drinking Water and Municipal Assistance

517 290-8817