

Rennaker, Joanne (DEQ)

From: Matta, Samir <SFMatta@lan-inc.com>
Sent: Wednesday, October 21, 2015 10:30 PM
To: Prysby, Mike (DEQ)
Subject: FW: Phosphoric Acid Feed.

Hi Mike,

Please see the response from Mary, DWSD.

Thanks.

Samir F. Matta, PE
 Team Leader



**Lockwood, Andrews
& Newnam, Inc.**
 A LEO A DALY COMPANY

1311 South Linden Road, Suite B • Flint, MI 48532
 2121 University Park Dr, Suite 100 • Okemos, MI 48864-6901
 D 517.819.2367 C 517.819.2367
www.lan-inc.com • sfmatta@lan-inc.com

From: Brent Wright [<mailto:bwright@cityofflint.com>]
Sent: Wednesday, October 21, 2015 12:44 PM
To: Green, Warren; Matta, Samir; Hansen, Jeff; Nakashima, Jeremy
Subject: Fwd: Phosphoric Acid Feed.

----- Forwarded message -----

From: Brent Wright <bwright@cityofflint.com>
Date: Wed, Oct 21, 2015 at 12:33 PM
Subject: Re: Phosphoric Acid Feed.
To: Mary Lynn Semegen <semegen@dwsd.org>

Thank you Mary.

On Oct 21, 2015 12:28 PM, "Mary Lynn Semegen" <semegen@dwsd.org> wrote:
 The Lake Huron plant tap residual ortho-phosphate is 1.0-1.2 ppm.

Sincerely,

Mary Lynn Semegen, Manager
 Water Quality Division
 Detroit Water and Sewerage Department
 Water Works Park Plant
 Room 208
 10100 E. Jefferson
 Detroit, Michigan 48214
 Phone: 313 926-8102
 FAX: 313 842-6418

semeegen@dwsd.org

City of Detroit
Mike Duggan, Mayor

On 10/21/2015 11:27 AM, Brent Wright wrote:
Mary

Do you know the feed in ppm that is coming from the Burtchville plant? We were under the impression the plant was only feeding a maintenance level of .4 to .5ppm. Our lab analysis show this to be higher.

Thank you

--
Brent Wright
Water Plant Supervisor
City of Flint
4500 N. Dort Hwy.
Flint, MI. 48505
Ph: 810.787.6537 ext. 3510
Fx: 810.787.3710

--
Brent Wright
Water Plant Supervisor
City of Flint
4500 N. Dort Hwy.
Flint, MI. 48505
Ph: 810.787.6537 ext. 3510
Fx: 810.787.3710

CONFIDENTIALITY AND PRIVILEGE NOTICE: This email communication, including any and all attachments, (collectively, this "Communication"), is intended solely for the person(s) to whom it is addressed. This Communication may contain information that is privileged, confidential and/or proprietary. Any unauthorized use, disclosure or copying of this Communication is strictly prohibited. If you have received this Communication in error, please contact the sender immediately and destroy any and all copies of this Communication.