

From: [Cook, Pat \(DEQ\)](#)
To: [Benzie, Richard \(DEQ\)](#)
Subject: RE: OCCT & WQPs
Date: Thursday, October 01, 2015 3:01:17 PM

After the installation of treatment, systems have to complete 12 months of follow-up Pb/Cu monitoring (2 consecutive – 6 month periods). After the follow-up monitoring is completed, the state reviews the results and the installed treatment. If the state is satisfied that the treatment is working and considers it optimal, they then designate the optimal water quality parameters within 6 months after the follow-up monitoring is completed.

pat

From: Benzie, Richard (DEQ)
Sent: Thursday, October 01, 2015 2:10 PM
To: Cook, Pat (DEQ)
Subject: OCCT & WQPs

Do you know the timing for us to establish WQPs once Flint installs orthophosphate? Do we set them immediately or some time after they have been in operation?