

From: [Benzie, Richard \(DEQ\)](#)
To: [Busch, Stephen \(DEQ\)](#); [Shekter Smith, Liane \(DEQ\)](#)
Cc: [Prysby, Mike \(DEQ\)](#); [Rosenthal, Adam \(DEQ\)](#)
Subject: RE: Preliminary Flint TTHM results
Date: Friday, August 28, 2015 1:23:07 PM

Yes. The city deserves to be told of our compliance determination just as much when they meet the standard as when they exceed it.

I would suggest the messaging from the city and possibly from us "express cautious optimism but acknowledge that the formation of disinfection byproducts can vary depending upon water quality, temperature and stagnation, all items the city is unable to control, so continued compliance is not assured. As always, the city will keep their customers informed."

From: Busch, Stephen (DEQ)
Sent: Friday, August 28, 2015 11:13 AM
To: Benzie, Richard (DEQ); Shekter Smith, Liane (DEQ)
Cc: Prysby, Mike (DEQ); Rosenthal, Adam (DEQ)
Subject: Preliminary Flint TTHM results

Richard and Liane,

A PRELIMINARY Flint TTHM compliance determination is attached. (The one month monitoring window doesn't officially end until Monday 8/31).

Note all 8 sites would now be in compliance with the LRAA, but we did have one sample this quarter over 80 ppb (site 7, 90.3 ppb). This will make messaging a little more difficult.

Shall we proceed, after August 31, to create a "TTHM return to compliance" letter?

Stephen Busch, P.E.
MDEQ Lansing District Coordinator
Office of Drinking Water and Municipal Assistance
Lansing and Jackson District Supervisor
517-643-2314
buschs@michigan.gov