
From: Matta, Samir [<mailto:SFMatta@lan-inc.com>]
Sent: Wednesday, October 21, 2015 10:34 PM
To: Prysby, Mike (DEQ)
Subject: FW: Flint Nail Test

Hi Mike,

Please see below from Brent as we discussed.

Thanks.

Samir F. Matta, PE

Team Leader



1311 South Linden Road, Suite B • Flint, MI 48532

2121 University Park Dr, Suite 100 • Okemos, MI 48864-6901

D 517.819.2367 C 517.819.2367

www.lan-inc.com • sfmatta@lan-inc.com

From: Brent Wright [<mailto:bwright@cityofflint.com>]
Sent: Wednesday, October 21, 2015 11:35 AM
To: Green, Warren
Cc: Matta, Samir; Howard Croft (hcroft@cityofflint.com); Lawrence, Charles; Hansen, Jeff; mglasgow@cityofflint.com; Nakashima, Jeremy
Subject: Re: Flint Nail Test

I have sent an email to Mary Semegen (head of DWSD water quality) regarding the feed rate coming from the Burtchville plant. I will inform you of her response upon receiving it.

From: Brent Wright [mailto:bwright@cityofflint.com]
Sent: Wednesday, October 21, 2015 7:51 AM
To: Green, Warren
Cc: Lawrence, Charles; Hansen, Jeff; Matta, Samir; mglasgow@cityofflint.com; Nakashima, Jeremy
Subject: Re: Flint Nail Test

On another note we are seeing a 1.24ppm of phosphate from DWSD. I was under the understanding they were only feeding a .5ppm. Any thoughts on what we should be feeding.

Thanks

On Wed, Oct 21, 2015 at 8:47 AM, Brent Wright <bwright@cityofflint.com> wrote:

Agree I see no difference.

On Wed, Oct 21, 2015 at 8:29 AM, Green, Warren <jwgreen@lan-inc.com> wrote:

Agree

J. Warren Green

On Oct 20, 2015, at 11:40 PM, Lawrence, Charles <cllawrence@lan-inc.com> wrote:

I don't know what the rest of you guys think, but looks like no difference between DWSD and Flint to me.

From: Hansen, Jeff
Sent: Tuesday, October 20, 2015 3:29 PM
To: Green, Warren
Cc: Matta, Samir; Brent Wright (bwright@cityofflint.com); 'mglasgow@cityofflint.com'; Lawrence, Charles; Nakashima, Jeremy
Subject: Flint Nail Test

After 1 week....

Jeffrey R. Hansen, PE