



**Lockwood, Andrews
& Newnam, Inc.**

A LEO A DALY COMPANY

2121 University Park Dr, Suite 100 • Okemos, MI 48864-6901

T 517.203.5437 D 517.203.5437

www.lan-inc.com • SFMatta@lan-inc.com

From: Prysby, Mike (DEQ) [<mailto:PRYSBYM@michigan.gov>]
Sent: Monday, July 13, 2015 11:55 AM
To: Matta, Samir
Cc: Hansen, Jeff; Busch, Stephen (DEQ)
Subject: RE: Flint WTP GAC Permit Application

Samir,

The revised plans received from you this morning along with the response and attachments from Jeff Hansen on July 8, 2015 address the majority of our comments sent on July 6, 2015. The removal and re-installation of the sand media; however, is not described. Please provide a description of the procedure to remove and re-install the sand filter media. An electronic response will be adequate.

Michael Prysby, P.E.
 District Engineer
 Office of Drinking Water and Municipal Assistance
 517 290-8817

From: Matta, Samir [<mailto:SFMatta@lan-inc.com>]
Sent: Friday, July 10, 2015 11:58 AM
To: Busch, Stephen (DEQ); Hansen, Jeff
Cc: Prysby, Mike (DEQ); Brent Wright (bwright@cityofflint.com); mglasgow@cityofflint.com; Green, Warren
Subject: RE: Flint WTP GAC Permit Application

Thanks Steve.

I am out of town today. I will drop the plans on Monday.

Enjoy your Weekend.

Samir Matta, PE
 Lockwood, Andrews & Newnam, Inc.
 (517)819-2367

----- Original message -----

From: "Busch, Stephen (DEQ)" <BUSCHS@michigan.gov>
Date: 07/10/2015 11:11 AM (GMT-05:00)
To: "Hansen, Jeff" <jrhansen@lan-inc.com>, "Matta, Samir" <SFMatta@lan-inc.com>

Cc: "Prysby, Mike (DEQ)" <PRYSBYM@michigan.gov>, "Brent Wright (bwright@cityofflint.com)" <bwright@cityofflint.com>, mglasgow@cityofflint.com, "Green, Warren" <jwgreen@lan-inc.com>
 Subject: RE: Flint WTP GAC Permit Application

Samir,

You may drop off revised plans today Friday or Monday. The other documents we can print.

If you come today give me a call at the number below. I will be in meetings from 12:00 2:00

If you come on Monday give call Mike, as he is scheduled to be back.

Thanks,

Stephen Busch, P.E.

Lansing and Jackson District Supervisor

Office of Drinking Water and Municipal Assistance

MDEQ

517-643-2314

From: Hansen, Jeff [mailto:jrhansen@lan-inc.com]

Sent: Wednesday, July 08, 2015 8:52 AM

To: Busch, Stephen (DEQ)

Cc: Prysby, Mike (DEQ); Brent Wright (bwright@cityofflint.com); mglasgow@cityofflint.com; Matta, Samir; Green, Warren

Subject: RE: Flint WTP GAC Permit Application

Steve,

In general response to your comments, our agreement with Flint is a design/build type so on the plans we have called out specific make/models to match what Flint currently uses for a number of items on your list rather than developing entire spec sections.