
From: Crooks, Jennifer <crooks.jennifer@epa.gov>
Sent: Wednesday, September 17, 2014 2:27 PM
To: Prysby, Mike (DEQ)
Subject: RE: FW: FW: (SDWA - FY14-121728-3715-CV) Referred to Region - Michigan

312-886-0244

From: Prysby, Mike (DEQ) [mailto:PRYSBYM@michigan.gov]
Sent: Wednesday, September 17, 2014 1:04 PM
To: Crooks, Jennifer
Subject: RE: FW: FW: (SDWA - FY14-121728-3715-CV) Referred to Region - Michigan

Jennifer...what is ur contact number....I wish to call you

Michael Prysby, P.E.
 District Engineer
 Office of Drinking Water and Municipal Assistance
 517 290-8817

From: Crooks, Jennifer [mailto:crooks.jennifer@epa.gov]
Sent: Wednesday, September 17, 2014 1:22 PM
To: Prysby, Mike (DEQ)
Subject: RE: FW: FW: (SDWA - FY14-121728-3715-CV) Referred to Region - Michigan

Again, many thanks to you, Mike, and the team at Flint WTP. I will call Savannah Young today. Sounds like she never contacted the Water Service Center. What is their phone number, so I can pass it on to her? Brent said that Mike Glasgow did a bacti and Chlorine at the other house on Irene; she may want to call for a bacti and chlorine too.

Mike—what is the “COF”? (Robert’s email below) How do the demolition contractors use the hydrants incorrectly, thus causing high iron?
 Jen

From: Prysby, Mike (DEQ) [mailto:PRYSBYM@michigan.gov]
Sent: Wednesday, September 17, 2014 12:02 PM
To: Crooks, Jennifer
Cc: Busch, Stephen (DEQ)
Subject: FW: FW: FW: (SDWA - FY14-121728-3715-CV) Referred to Region - Michigan

Jennifer,

I received the response from the Flint WTP staff...nothing from that person; however, a complaint from another resident on that street. Robert Bincsik just informed me that he is sending out a crew to flush several hydrants on that street to help alleviate the iron in the water.

Michael Prysby, P.E.
District Engineer
Office of Drinking Water and Municipal Assistance
517 290-8817

From: Brent Wright [mailto:bwright@cityofflint.com]
Sent: Wednesday, September 17, 2014 12:56 PM
To: Prysby, Mike (DEQ)
Subject: Re: FW: FW: (SDWA - FY14-121728-3715-CV) Referred to Region - Michigan

No one here has spoke with this person, but Mike Glasgow did go to a Brooke Awad's house yesterday on Irene and sampled her water for chlorine and bacti. Her complaint was cloudy water.

On Wed, Sep 17, 2014 at 12:36 PM, Prysby, Mike (DEQ) <PRYSBYM@michigan.gov> wrote:

Jennifer,

Below is the response from Water Service Center (WSC). The location was not in the BWA area; however, as Robert indicates, this person did not contact the WSC. Let's hold-off on calling her until I hear whether the Flint WTP staff has had any involvement with this complaint. Robert also indicate local contractors using hydrants improperly as a potential cause.

Michael Prysby, P.E.
District Engineer
Office of Drinking Water and Municipal Assistance
517 290-8817

From: Robert Bincsik [mailto:rbincsik@cityofflint.com]
Sent: Wednesday, September 17, 2014 12:13 PM
To: Prysby, Mike (DEQ)