
From: John O'Malia <jcomalia@gmail.com>
Sent: Wednesday, March 19, 2014 7:25 PM
To: Matt Raysin
Cc: Prysby, Mike (DEQ); Bloemker, Jon (DEQ); Busch, Stephen (DEQ); Tharp, Ed; Osborn, Larry; Lynnette Meinz; Clifford Gordon; Elgar Brown
Subject: Re: FW: FW: KWA - LHWI Septic system

Well done and sounds like now resolved.
 John O'

On Wednesday, March 19, 2014, Matt Raysin <M_RAYSIN@gdcwws.com> wrote:

We were provided the documents from the sanitarian for the intermediate pump station. As shown on the permit the minimum distance is 10 feet. We will have J&H address the distance from the pump station as discussed in the review meeting.

From: Clifford Gordon [mailto:cgordon@jhens.com]
Sent: Wednesday, March 19, 2014 10:02 AM
To: Matt Raysin
Cc: Ed Tharp; Tom Gossiaux; John O'Brien; Steven Wordelman; Larry Osborn
Subject: Re: FW: KWA - LHWI Septic system

Matt:

You wanted to be kept informed. Please see below and attachment.

Cliff

Clifford M. Gordon P.E. CGWP

*Principal
 Director of Groundwater & Environmental Modeling*

*Cell: 419-509-7520
 Phone 419-473-9611*

FAX: 419-473-8924

Visit our Website: www.jheng.com

EVERY DAY 1400 children die from diseases directly related to unsanitary drinking water... Give water....give life.

>>>

From: "Kevin Cook" <kcook@chmpinc.com>
To: "Clifford Gordon" <CGORDON@jheng.com>
CC: "Jeff Szczepanski" <jszczepanski@chmpinc.com>
Date: 3/19/2014 9:48 AM
Subject: FW: KWA - LHWI Septic system

Cliff-

Response from sanitarian. I believe he has changed what was originally required although it does indicate 10- minimum on the permit (copy attached). It seems that his criteria now matches that of the MDEQ. I recommend you update the plan accordingly (move from 5' to 10'). Please note his additional comment about a driveway crossing as this is something new as well. Are you including a copy of the permit in the bidding documents?

Also, please see the marked up detail from sheet C-6.1. Please modify to match the information on the permit. Sorry for the late revision but I get the feeling that the Sanitarian didn't really look at the plans we submitted. Rather just used his chicken scratch permit sheet. Better to catch now then after bids.

Regards,

Kevin Cook

From: Cameron, Lowell [<mailto:lcameron@nd.stclaircounty.org>]
Sent: Wednesday, March 19, 2014 9:06 AM
To: 'Kevin Cook'
Subject: RE: KWA - LHWI Septic system

Hi Kevin,