

The septic tank must be a minimum of ten foot from the building. If the effluent line (line from the tank to the field) is to be under the driveway it can be encased with a larger Sed. 40 pipe, or steel pipe to prevent possible damage from driving over it. Hope all is going well. Call me at 810-987-5306 if any questions.

Lowell Cameron

REHS/Coordinator

ST. CLAIR COUNTY HEALTH DEPARTMENT

From: Kevin Cook [<mailto:kcook@chmpinc.com>]
Sent: Tuesday, March 18, 2014 16:16
To: Cameron, Lowell
Cc: Clifford Gordon; Jeff Szczepanski
Subject: KWA - LHWI Septic system

Lowell-


The following concern was raised by the State as a part of their building plan review. Can you please review and find a common ground so we can get approved.

MDEQ was concerned about the septic tank being too near to the building. MDEQ said it should be place 10 minimum from the building; we were under the impression that the health department did not want it too far from the building. I know the Health Department moved it from our original location which was further away. I think their concern was driving over the pipe from the building to the septic. Please provide clarification on the reason why it was moved closer to the building.

Thanks,

Kevin E. Cook, P.E.

Director of Engineering



CHMP, INC.

5198 Territorial Road

Grand Blanc, MI 48439

Telephone: (810) 695-5910

Fax: (810) 695-0660

This email and files with it are confidential and are solely for the use of the addressee. If you received this in error, please notify the sender immediately by e-mail and delete this e-mail from your system. E-mail messages and files cannot be guaranteed to be secure, error-free or reproduce accurately on your system. The sender therefore does not accept liability for errors or omissions. Additional information regarding our policy on electronic documents is available at <http://WWW.JHENG.COM>