
From: Prysby, Mike (DEQ)
Sent: Thursday, February 26, 2015 11:06 AM
To: Rosenthal, Adam (DEQ)
Subject: FW: HIGH LEAD: FLINT Water testing Results
Attachments: 212 Browning (Pb & Cu).pdf; Flint Technical Advisory Team List_R1.pdf

fyi

Michael Prysby, P.E.
 District Engineer
 Office of Drinking Water and Municipal Assistance
 517 290-8817

From: Crooks, Jennifer [mailto:crooks.jennifer@epa.gov]
Sent: Thursday, February 26, 2015 10:53 AM
To: Busch, Stephen (DEQ); Prysby, Mike (DEQ)
Cc: Poy, Thomas; Deltoral, Miguel
Subject: HIGH LEAD: FLINT Water testing Results

Hi, Steve and Mike. Thanks for talking with me yesterday, Steve, about the most recent TTHM results. We'll look forward to receiving them whenever you get them back from the lab.

However, the main purpose of my email is to alert you to the high lead levels reported to a citizen yesterday by Flint Water Dept. I have been discussing the water situation with LeeAnn Walters since January, and she has been talking with Mike Glasgow at the plant about the black sediment in her water. (HUGE KUDOs to MIKE!!) He did test it to find that the iron levels were greater than his test would go; GT 3.3. But, because the iron levels were so high, he suggested testing for lead and copper. WOW!!!! Did he find the LEAD! **104 ppb**. She has 2 children under the age of 3... Big worries here.

So, Steve, this goes back to what you and I were talking about yesterday. That the different chemistry water is leaching out contaminants from the insides of the biofilms inside the pipes. I think Lead is a good indication that other contaminants are also present in the tap water, that obviously were not present in the compliance samples taken at the plant. VOC/SOC and inorganics/metals would be good samples to start with to take at the tap. And since Ms. Walters' drinking water is showing the high lead levels, her tap water would be a good place to start, I think.

We also talked about Dr. Joan Rose from Michigan State being on the Flint Tech Advisory Committee—you also mentioned that someone from the Dept of Community Health was on the Committee. I'm thinking that Dr. Rose would want to dive further into this, since there's actual evidence that the water is leaching contaminants from the biofilms; or Dept of Community Health would want to get involved and look at this from an epidemiological perspective. (She and her family are also exhibiting the rashes when exposed to the water, and her daughter's hair is falling out in clumps.)

Maybe MSU could authorize the payment of the analyses for these samples? Or Dept of Community Health?

The citizen's name is:
 LeeAnn Walters
 212 Browning Ave

Flint, MI 48507
 [REDACTED]
 [REDACTED]

Jennifer

From: Lea Moste [<mailto:lwalters313@gmail.com>]
Sent: Thursday, February 26, 2015 9:08 AM
To: Crooks, Jennifer
Subject: Fwd: Re: Water testing Results

----- Forwarded message -----

From: "Michael Glasgow" <mglasgow@cityofflint.com>
 Date: Feb 26, 2015 7:55 AM
 Subject: Re: Water testing Results
 To: "Lea Moste" <lwalters313@gmail.com>
 Cc:

Lee,

Here are your Lead & Copper Results. This number is very high, 104 ppb of lead. In the last few months over 100 samples have been tested and only 2 were over the 15 ppb regulatory limit, and the highest level I have seen is 37 ppb. I will pass this info to Mr. Croft so he is aware. I will send the sample I collected from your kitchen faucet today for a complete metals test (12 different metals), to see what the level is without letting the water stagnate over night. I'm hoping that value will be much, but we will have to see. Sorry for this news, but I wanted to let you know right away.

Mike

On Tue, Feb 24, 2015 at 1:50 PM, Michael Glasgow <mglasgow@cityofflint.com> wrote:

Lee,

I will bring a copy of last years annual report when I stop by tomorrow. The annual report from 2014 must be delivered to residents by July 1st of this year. I imagine we may have it complete by June.

Mike

On Fri, Feb 20, 2015 at 1:00 AM, Lea Moste <lwalters313@gmail.com> wrote:

Mike,

Thank you for the water reports and we already planned to see you on the 25th at 10:00am. I was wondering if you know who I need to talk to in the water plant to obtain the Annual Drinking Water Report from last year. According to the EPA website there is link to access but when you click on it, it cannot be accessed. Was also curious if there is an expected time frame for this years report due to the switch. If you can be of any assistance I would appreciate it.

Thank You
 LeeAnne Walters

On Thu, Feb 19, 2015 at 12:47 PM, Michael Glasgow <mglasgow@cityofflint.com> wrote: