

Thanks.

Stephen Busch, P.E.
MDEQ Lansing District Coordinator
Office of Drinking Water and Municipal Assistance
Lansing and Jackson District Supervisor
517-643-2314
buschs@michigan.gov

From: Antil, Jeffrey (DEQ)
Sent: Tuesday, July 21, 2015 9:46 AM
To: Drake, Jerry (DEQ); Busch, Stephen (DEQ)
Subject: Monroe South County DBPs exceedance
Importance: High

FYI!
MSC violated the THM MCL of 80 ppb with this last round of monitoring conducted July 7, 2015.
ALL of their 4 sites were extremely high on TTHMs this Q – 153, 126, 151, 130; DBPS 1, 2, 3, 4, respectively. Their LRAA for DBP1 (12924 Allenhurst) is 93 and their 4Q OEL becomes 114 ppb. Previous highs on TTHMs was 126 back in 4Q 2012 and a 94 in April 2015 from the same DBP1 site on Allenhurst.

I will give Ed a call here and request the OEL report by 10/21/15 and I'll prepare the violation letters.

Thanks,
Jeff

Jeff Antil
Drinking Water Analyst
Office of Drinking Water & Municipal Assistance
Department of Environmental Quality
301 East Louis Glick Hwy
Jackson, Michigan, 49201
(p) 517.780.7840
(f) 517.780.7855
antili@michigan.gov