

Are we providing instruction where to place the sample location identifier (i.e. KC-P1, KC-P2, KC-A1...)? I would suggest the Sampling Point description box if the collection address in that same section of the form is already completed.

Perhaps a sample Request for Analysis form filled out with information attached and refer in the document as Attachment 1? (Including billing number?)

Step 4 Prior to Sample Collection – I would move this higher to position Step 3 and right after Step 2 identify taps to be sampled if there is a home visit the day before or so to inspect plumbing. Otherwise if Step 1 & 2 is on the day of sample collection, move this above the current Step 1.

Wondering about recommended morning arrival time versus the family's morning routine to ensure no water has flowed through the plumbing; such as contacting the residents for appropriate appointment time.

Step 5 OK but we are also instructing to identify the sample as KC-P1, etc. so this part should be modified.

Step 6 – consecutive sampling

I see that these are for home samples, but I was wondering if there might be apartment samples, one former single family home split into multiple units or multi-family apartment building and wondering how these instructions would be applied for the consecutive sampling portion. How to control the water shut off period?

If multi-family apartment building, how can DHHS staff determine if there is a treatment system (softener, filters, etc.)?

-Is there more clarification needed for how to deliver the samples to the DEQ DWL? Is postage also provided, mailing boxes, or instructions to ship by UPS not US mail?

From: Shekter Smith, Liane (DEQ)

Sent: Monday, November 09, 2015 1:46 PM

To: Krisztian, George (DEQ)

Cc: Busch, Stephen (DEQ); Benzie, Richard (DEQ); Graham, Lois (DEQ); Devereaux, Tracy Jo (DEQ); Sygo, Jim (DEQ); Prysby, Mike (DEQ)

Subject: DRAFT residential sampling protocol for DHHS EBL investigations

Comments?

I'd like to send this to DHHS and to EPA by the end of the day if there are no objections.

From: Krisztian, George (DEQ)
Sent: Tuesday, November 10, 2015 1:20 PM
To: Shaler, Karen (DEQ); Thelen, Mary Beth (DEQ)
Subject: FW: Freeman, Brownell and Eisenhower

FYI

George L. Krisztian
Flint Action Plan Coordinator
Laboratory Director
Michigan Department of Environmental Quality
Desk ph (517) 284-6719
Cell ph PPI

From: Henry, James [mailto:jhenry@gchd.us]
Sent: Tuesday, November 10, 2015 1:05 PM
To: Krisztian, George (DEQ); Vorce, Susan (DEQ)
Cc: MVALACAK@gchd.us
Subject: RE: Freeman, Brownell and Eisenhower

Hello George and Susan,
Please withdraw GCHD's Freedom of Information Act request for Freeman Elementary School, Flint (FOIA 0731-16).

George, Thanks for following up with me. Just as a reminder, GCHD would like to assist MDEQ with collecting water samples at the Flint Schools and other locations within the City of Flint, as needed. I have confirmed staff availability and our finance department calculated \$92/hr. for reimbursement. GCHD staff are required to be paid overtime (1.5 x 92) 138/hr. when working outside the hours between 8-5pm. Please let me know if you would like our assistance.

Also, just as an FYI, I am having GCHD staff visit all Flint schools to confirm that consumption of water is being prevented.

Thanks Jim

Jim Henry RS, MBA
Environmental Health Supervisor
Genesee County Health Department www.gchd.us
630 S. Saginaw St., Suite 4
Flint, MI 48502-1540
Phone (810) 257-3618 Fax (810) 257-3125
E-mail jhenry@gchd.us

