
From: Michael Glasgow <mglasgow@cityofflint.com>
Sent: Monday, November 02, 2015 5:18 PM
To: Krisztian, George (DEQ)
Subject: School testing for lead & copper

Follow Up Flag: Follow up
Flag Status: Flagged

George,

I have recently received some inquiries regarding lead & copper testing at a couple of local schools and wanted to pass along the information. The International Academy of Flint had collected samples using our process for residential homes, while we were offering free testing to residents. If there is anything I can do to help facilitate testing, please let me know.

1. International Academy of Flint, 2820 S. Saginaw St. Flint, MI 48503 (810) 600-5000.
2. St. Paul Lutheran, 402 S. Ballenger Hwy. Flint, MI 48532 (810) 239-6733

Thank you,

—

Mike Glasgow
Utilities Administrator
City of Flint
1101 S. Saginaw St.
Flint, MI 48502
(810)766-7135 ext. 2602

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**



P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184

**Sample Number
LF97352**

Official Laboratory Report

Report To: TAMMY WALL
38900 W HURON RIVER DR
ROMULUS MI 48174

System Name/Owner: CITY OF FLINT
Collection Address: 3707 DAKOTA AVE, FLINT
Collected By: MATT DUNCAN
County: Genesee
Sample Point: KF-A1 KITCHEN

Date Collected: 12/18/2015 09:38
Date Received: 12/18/2015 15:15

TESTING INFORMATION		REGULATORY INFORMATION		
Analyte Name	Result (mg/L)	Date Tested	Reporting Limit (mg/L)	Action Level (mg/L)
Copper	Not detected	12/21/2015	0.05	1.3
Lead	Not detected	12/21/2015	0.001	0.015

Understanding Your Lead Results:

- Lead results are reported in mg/L
 - To turn mg/L into parts per billion or ppb move the decimal 3 places to the right
 - For example 0.019 mg/L becomes 19 ppb and 0.004 becomes 4 ppb
 - Not Detected means that the amount of lead in your water was less than 1 ppb
 - The Reporting Limit is the smallest number that can be reported
 - For Lead the Reporting Limit is 1 ppb
 - For Copper the Reporting Limit is 50 ppb
 - The Action Level is the number that is used to help determine regulatory compliance
 - The Action Level for Lead is 15 ppb
 - The Action Level for Copper is 1,300 ppb
- No matter what your lead result is, you should continue to use a filter until the Public Health Emergency Declaration has been lifted.**

Call your County Health Department at the number below if you have questions
Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603