
From: Howard Croft <hcroft@cityofflint.com>
Sent: Wednesday, September 17, 2014 2:53 PM
To: Prysby, Mike (DEQ); Busch, Stephen (DEQ)
Subject: Boil Water Advisory Report
Attachments: Boil Water Overview_Memorandum.pdf

Mike,

I wanted you to have a copy of the report I sent to the Mayor and EM today as an overview of the recent boil water advisory. Please let me know if anything here appears amiss.

Thanks,

--

Howard Croft
Public Works Director
City of Flint
1101 S. Saginaw Street
Flint, MI 48502
PH# 810.766.7346 Ext.2043
hcroft@cityofflint.com



Dayne Walling
Mayor

CITY OF FLINT
Department of Public Works

Darnell Earley, ICMA-CM, MPA
Emergency Manager

Howard Croft
Director

MEMORANDUM

TO: Darnell Earley, Emergency Manager
Dayne Walling, Mayor

FROM: Howard Croft, Public Works Director

DATE: September 16, 2014

RE: Recent Boil Water Advisory

Mr. Earley,

I have compiled a bullet point list of the pertinent events surrounding the recent boil water advisory in the City of Flint. I have separated the events into five categories and attempted to condense them into a comprehensive sequence for your review.

OVERVIEW

- On Friday September 5, 2014 the City of Flint issued a boil water advisory to residents in two of ten test areas around the city.
- The advisory was due to multiple positive tests for "total coliform" and the area covered approximately 9 square miles.
- On Sunday September 7, 2014 the City expanded the advisory to include another of the ten test areas due to a subsequent positive total coliform test.
- The boil water advisories were lifted on Tuesday September 9th at 5:00pm after consultation with the DEQ.