
From: Rennaker, Joanne (DEQ)
Sent: Thursday, September 03, 2015 9:07 AM
To: Prysby, Mike (DEQ)
Subject: FW: Flint TTHM 3rd quarter letter
Attachments: Flint DBP 3Q15-revised.doc

For your records.

From: Busch, Stephen (DEQ)
Sent: Wednesday, September 02, 2015 9:14 AM
To: Rennaker, Joanne (DEQ)
Cc: Prysby, Mike (DEQ); Rosenthal, Adam (DEQ)
Subject: Flint TTHM 3rd quarter letter

Jo Anne,

I believe the attached is ready to be finalized.

I would like a pdf of the signed letter to email over to members of the legislature.

Stephen Busch, P.E.
MDEQ Lansing District Coordinator
Office of Drinking Water and Municipal Assistance
Lansing and Jackson District Supervisor
517-643-2314
buschs@michigan.gov



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
LANSING DISTRICT OFFICE



DAN WYANT
DIRECTOR

September 2, 2015

Mr. Brent Wright, Operations Supervisor
City Of Flint – Department of Public Works
Flint Water Plant
4500 North Dort Highway
Flint, Michigan 48505

WSSN: 02310

Dear Mr. Wright:

SUBJECT: City of Flint – Water Supply
Return to Compliance Total Trihalomethanes (TTHM)
3rd Quarter 2015 Monitoring Period

The Department of Environmental Quality (DEQ), Office of Drinking Water and Municipal Assistance (ODWMA), records show that the City of Flint (City) has returned to compliance with the Michigan Safe Drinking Water Act, 1976 PA 399, as amended (Act 399); R 325.10610, *Maximum contaminant levels for disinfection byproducts (MCLs)*, of the 1979 Administrative Code.

In accordance with Administrative Rule 610 (R 325.10610, *MCLs for disinfection byproducts*), the MCL for the disinfection byproduct TTHM is 0.080 milligrams per liter (mg/L). Compliance is determined based on a Locational Running Annual Average (LRAA) at each monitoring location. As listed in the table below, our records show that the LRAA all eight of the City's TTHM compliance sampling sites now comply with this standard based on the last four quarterly monitoring periods, ending August 31, 2015. This return to compliance regarding TTHM's began on September 1, 2015, and will continue as long as the LRAA at each of the City's TTHM compliance sampling sites remain below this standard.

TTHM Results (mg/L)	11/20/14	2/17/15	5/18/15	8/18/15	LRAA	OEL
DBP1 McDonalds 3719 Davison	0.059	0.0162	0.0514	0.0755	0.050	0.055
DBP2 Liquor Palace 3302 South Dort Highway	0.033	0.0168	0.0635	0.0532	0.042	0.047
DBP3 North Flint Auto 6204 North Saginaw St.	0.041	0.0149	0.0452	0.0426	0.036	0.036
DBP4 University Market 2501 Flushing Road	0.094	0.0245	0.0598	0.0706	0.062	0.056
DBP5 Taco Bell 3606 Corunna Road	0.034	0.0151	0.0547	0.0619	0.042	0.049
DBP6 Rite-Aid Pharmacy 5018 Clio Road	0.054	0.0192	0.0605	0.0595	0.048	0.050
DBP7 Salem Housing 3216 MLK Boulevard	0.050	0.0285	0.0727	0.0903	0.060	0.070
DBP8 BP Gas Station	0.036	0.0199	0.0461	0.0549	0.039	0.044