
From: Prysby, Mike (DEQ)
Sent: Thursday, February 26, 2015 11:25 AM
To: Crooks, Jennifer
Cc: Busch, Stephen (DEQ); Rosenthal, Adam (DEQ)
Subject: RE: HIGH LEAD: FLINT Water testing Results

Jennifer,

I recall Adam showing me a high lead/copper sample result (perhaps it was this one)....as part of the city's routine lead-copper monitoring. If so, it was a stagnated sample as part of the sampling protocol. Adam mentioned that all other samples were below the AL...and the city will not exceed the lead AL. I will confirm this. The city; however, needs to take further action to help address Ms. Walter's concern. The type of plumbing needs to be identified and sample tap location within the premise plumbing. They should offer to re-sample for PB after flushing the tap to demonstrate that flushing the tap will reduce the lead concentration. The city also needs to provide other lead-reduction strategies to Mrs. Walters.

Michael Prysby, P.E.
District Engineer
Office of Drinking Water and Municipal Assistance
517 290-8817

From: Crooks, Jennifer [mailto:crooks.jennifer@epa.gov]
Sent: Thursday, February 26, 2015 10:53 AM
To: Busch, Stephen (DEQ); Prysby, Mike (DEQ)
Cc: Poy, Thomas; Deltoral, Miguel
Subject: HIGH LEAD: FLINT Water testing Results

Hi, Steve and Mike. Thanks for talking with me yesterday, Steve, about the most recent TTHM results. We'll look forward to receiving them whenever you get them back from the lab.

However, the main purpose of my email is to alert you to the high lead levels reported to a citizen yesterday by Flint Water Dept. I have been discussing the water situation with LeeAnn Walters since January, and she has been talking with Mike Glasgow at the plant about the black sediment in her water. (HUGE KUDOs to MIKE!!) He did test it to find that the iron levels were greater than his test would go; GT 3.3. But, because the iron levels were so high, he suggested testing for lead and copper. WOW!!!! Did he find the LEAD! 104 ppb. She has 2 children under the age of 3... Big worries here.

So, Steve, this goes back to what you and I were talking about yesterday. That the different chemistry water is leaching out contaminants from the insides of the biofilms inside the pipes. I think Lead is a good indication that other contaminants are also present in the tap water, that obviously were not present in the compliance samples taken at the plant. VOC/SOC and inorganics/metals would be good samples to start with to take at the tap. And since Ms. Walters' drinking water is showing the high lead levels, her tap water would be a good place to start, I think.

We also talked about Dr. Joan Rose from Michigan State being on the Flint Tech Advisory Committee—you also mentioned that someone from the Dept of Community Health was on the Committee. I'm thinking that Dr. Rose would want to dive further into this, since there's actual evidence that the water is leaching contaminants from the biofilms; or Dept of Community Health would want to get involved and look at this from an epidemiological perspective. (She and her family are also exhibiting the rashes when exposed to the water, and her daughter's hair is falling out in clumps.)

Maybe MSU could authorize the payment of the analyses for these samples? Or Dept of Community Health?

The citizen's name is:

LeeAnn Walters
212 Browning Ave
Flint, MI 48507
616-212-6233
lwalters313@gmail.com

Jennifer

From: Lea Moste [<mailto:lwalters313@gmail.com>]

Sent: Thursday, February 26, 2015 9:08 AM

To: Crooks, Jennifer

Subject: Fwd: Re: Water testing Results

----- Forwarded message -----

From: "Michael Glasgow" <mglasgow@cityofflint.com>

Date: Feb 26, 2015 7:55 AM

Subject: Re: Water testing Results

To: "Lea Moste" <lwalters313@gmail.com>

Cc:

Lee,

Here are your Lead & Copper Results. This number is very high, 104 ppb of lead. In the last few months over 100 samples have been tested and only 2 were over the 15 ppb regulatory limit, and the highest level I have seen is 37 ppb. I will pass this info to Mr. Croft so he is aware. I will send the sample I collected from your kitchen faucet today for a complete metals test (12 different metals), to see what the level is without letting the water stagnate over night. I'm hoping that value will be much, but we will have to see. Sorry for this news, but I wanted to let you know right away.

Mike

On Tue, Feb 24, 2015 at 1:50 PM, Michael Glasgow <mglasgow@cityofflint.com> wrote:

Lee,

I will bring a copy of last years annual report when I stop by tomorrow. The annual report from 2014 must be delivered to residents by July 1st of this year. I imagine we may have it complete by June.

Mike

On Fri, Feb 20, 2015 at 1:00 AM, Lea Moste <lwalters313@gmail.com> wrote:

Mike,