
From: Prysby, Mike (DEQ)
Sent: Wednesday, September 17, 2014 1:02 PM
To: Crooks, Jennifer (crooks.jennifer@epa.gov)
Cc: Busch, Stephen (DEQ)
Subject: FW: FW: FW: (SDWA - FY14-121728-3715-CV) Referred to Region - Michigan

Jennifer,

I received the response from the Flint WTP staff....nothing from that person; however, a complaint from another resident on that street. Robert Bincsik just informed me that he is sending out a crew to flush several hydrants on that street to help alleviate the iron in the water.

Michael Prysby, P.E.
District Engineer
Office of Drinking Water and Municipal Assistance
517 290-8817

From: Brent Wright [mailto:bwright@cityofflint.com]
Sent: Wednesday, September 17, 2014 12:56 PM
To: Prysby, Mike (DEQ)
Subject: Re: FW: FW: (SDWA - FY14-121728-3715-CV) Referred to Region - Michigan

No one here has spoke with this person, but Mike Glasgow did go to a Brooke Awad's house yesterday on Irene and sampled her water for chlorine and bacti. Her complaint was cloudy water.

On Wed, Sep 17, 2014 at 12:36 PM, Prysby, Mike (DEQ) <PRYSBYM@michigan.gov> wrote:

Jennifer,

Below is the response from Water Service Center (WSC). The location was not in the BWA area; however, as Robert indicates, this person did not contact the WSC. Let's hold-off on calling her until I hear whether the Flint WTP staff has had any involvement with this complaint. Robert also indicate local contractors using hydrants improperly as a potential cause.

Michael Prysby, P.E.

District Engineer

Office of Drinking Water and Municipal Assistance

517 290-8817

From: Robert Bincsik [mailto:rbincsik@cityofflint.com]

Sent: Wednesday, September 17, 2014 12:13 PM

To: Prysby, Mike (DEQ)

Cc: bwright@cityofflint.com

Subject: Re: FW: (SDWA - FY14-121728-3715-CV) Referred to Region - Michigan

To my knowledge we never received a complaint from this address. This would've been south of the effected area and wouldn't have been in the boil water notice. I will have someone go out and flush the hydrants near this address but obviously I have to be made aware of the problem first in order to be able to fix it. I'm quite certain its iron she is seeing in her water and this has been a problem this year in the COF given all the demolition contractors using hydrants improperly.

On Wed, Sep 17, 2014 at 11:13 AM, Prysby, Mike (DEQ) <PRYSBYM@michigan.gov> wrote:

Brent, Robert,

As part of my follow-up to EPA on this latest complaint, provide a summary of action taken and/or communication by the city to address Savanna Young's concerns?

Michael Prysby, P.E.

District Engineer

Office of Drinking Water and Municipal Assistance

517 290-8817

From: Crooks, Jennifer [mailto:crooks.jennifer@epa.gov]

Sent: Wednesday, September 17, 2014 11:04 AM

To: Busch, Stephen (DEQ); Prysby, Mike (DEQ)