
From: Krisztian, George (DEQ)
Sent: Wednesday, December 23, 2015 10:09 AM
To: DeBruyn, Dana (DEQ)
Subject: Potter, Holmes and Admin data
Attachments: Potter Elementary Draft.pdf; Holmes and Admin Draft.xlsx

Hi Dana,

Attached is the data for Potter Elementary, Holmes STEM Academy and the Administration building.

In case I don't see you, Merry Christmas!

George

George L. Krisztian
Flint Action Plan Coordinator
Laboratory Director
Michigan Department of Environmental Quality
Desk ph (517) 284-6719
Cell ph PPI

Potter Elementary
2500 North Averill Avenue
Flint, Michigan 48506

ANALYTE	RESULT	ANALYTE	RESULT	Sample Description	Site Code	Site Description
Lead	0.001	Copper	0.00	01CF001-RM22	CA1	First Sequential Sample
Lead	0.000	Copper	0.00	01CF001-RM22	CA2	Second Sequential Sample
Lead	0.000	Copper	0.00	01CF001-RM22	CA3	Third Sequential Sample
Lead	0.000	Copper	0.00	01CF001-RM22	CA4	Forth Sequential Sample
Lead	0.000	Copper	0.00	01CF001-RM22	CA5	Fifth Sequential Sample
Lead	0.000	Copper	0.00	01CF001-RM22	CA6	Sixth Sequential Sample
Lead	0.000	Copper	0.00	01CF001-RM22	CA7	Seventh Sequential Sample
Lead	0.000	Copper	0.00	01CF001-RM22	CA8	Eighth Sequential Sample
Lead	0.000	Copper	0.00	01CF001-RM22	CA9	Ninth Sequential Sample
Lead	0.000	Copper	0.00	01CF001-RM22	CA10	Tenth Sequential Sample
Lead	0.002	Copper	0.06	01CF013-RM12	CB1	First Sequential Sample
Lead	0.001	Copper	0.05	01CF013-RM12	CB2	Second Sequential Sample
Lead	0.000	Copper	0.05	01CF013-RM12	CB3	Third Sequential Sample
Lead	0.000	Copper	0.05	01CF013-RM12	CB4	Forth Sequential Sample
Lead	0.000	Copper	0.05	01CF013-RM12	CB5	Fifth Sequential Sample
Lead	0.000	Copper	0.05	01CF013-RM12	CB6	Sixth Sequential Sample
Lead	0.000	Copper	0.05	01CF013-RM12	CB7	Seventh Sequential Sample
Lead	0.000	Copper	0.05	01CF013-RM12	CB8	Eighth Sequential Sample
Lead	0.000	Copper	0.05	01CF013-RM12	CB9	Ninth Sequential Sample
Lead	0.000	Copper	0.05	01CF013-RM12	CB10	Tenth Sequential Sample
Lead	0.005	Copper	0.17	01CF035-RM 2A	CC1	First Sequential Sample
Lead	0.003	Copper	0.18	01CF035-RM 2A	CC2	Second Sequential Sample
Lead	0.002	Copper	0.18	01CF035-RM 2A	CC3	Third Sequential Sample
Lead	0.003	Copper	0.18	01CF035-RM 2A	CC4	Forth Sequential Sample
Lead	0.002	Copper	0.18	01CF035-RM 2A	CC5	Fifth Sequential Sample
Lead	0.002	Copper	0.18	01CF035-RM 2A	CC6	Sixth Sequential Sample
Lead	0.002	Copper	0.18	01CF035-RM 2A	CC7	Seventh Sequential Sample
Lead	0.002	Copper	0.18	01CF035-RM 2A	CC8	Eighth Sequential Sample
Lead	0.002	Copper	0.17	01CF035-RM 2A	CC9	Ninth Sequential Sample
Lead	0.002	Copper	0.17	01CF035-RM 2A	CC10	Tenth Sequential Sample
Lead	0.009	Copper	0.12	01CF037-RM 3B	CD1	First Sequential Sample
Lead	0.001	Copper	0.07	01CF037-RM 3B	CD2	Second Sequential Sample
Lead	0.001	Copper	0.00	01CF037-RM 3B	CD3	Third Sequential Sample
Lead	0.000	Copper	0.00	01CF037-RM 3B	CD4	Forth Sequential Sample
Lead	0.000	Copper	0.00	01CF037-RM 3B	CD5	Fifth Sequential Sample
Lead	0.000	Copper	0.00	01CF037-RM 3B	CD6	Sixth Sequential Sample
Lead	0.000	Copper	0.00	01CF037-RM 3B	CD7	Seventh Sequential Sample
Lead	0.000	Copper	0.00	01CF037-RM 3B	CD8	Eighth Sequential Sample
Lead	0.000	Copper	0.00	01CF037-RM 3B	CD9	Ninth Sequential Sample
Lead	0.000	Copper	0.00	01CF037-RM 3B	CD10	Tenth Sequential Sample

Note: Results of "Not Detected" have been converted to a numerical value of zero to allow for ease of sorting.

Results in RED exceed 15 ppb for lead or 1.3 ppm for Copper

1 ppb = 0.001 mg/L