

- ✱ The sentence "Other equipment that may use city water:" could be read as permissive. Suggest changing may to "might be connected to."

From: Shekter Smith, Liane (DEQ)

Sent: Tuesday, October 13, 2015 2:07 PM

To: Dykema, Linda D. (DHHS); Groetsch, Kory J. (DHHS)

Cc: Krisztian, George (DEQ); DeBruyn, Dana (DEQ); Busch, Stephen (DEQ); Devereaux, Tracy Jo (DEQ); Besey, Kevin (MDARD)

Subject: DRAFT DELIBERATIVE. NOT SUBJECT TO FOIA - Draft recommendations for restaurants from MDARD

Importance: High

Linda and Kory –

The attached document was created by MDARD and modified by DEQ NCWS staff. MDARD plans to e-mail this to food establishments in the flint area and also provide it to the Genesee County LHD for their use. MDARD is anxious to get this out to restaurants but would like your review/comments prior to finalizing.

This is a request for content review. They'll take care of making it look nice.

Comments can go back to MDARD directly (Kevin Besey), but I'd like to be cc'd also so that we can see your comments also. That will help us craft future messages.

Thanks.

From: Busch, Stephen (DEQ)
Sent: Wednesday, November 25, 2015 6:46 AM
To: Madziar, Joseph (LARA); Neuman, Andy (LARA); Krisztian, George (DEQ)
Cc: Devereaux, Tracy Jo (DEQ); DeBruyn, Dana (DEQ); Sygo, Jim (DEQ); Shekter Smith, Liane (DEQ)
Subject: Preliminary and Deliberative - Draft assessment review - Brownell
Attachments: Brownell STEM Academy.docx

Attached is the draft report for the school sampling conducted at Brownell STEM Academy school for comment. Joe and Andy please let me know if there are any issues with content.

I believe I have incorporated formatting consistent with the last report for Eisenhower.

Note faucet CF007 was above the take action level for both lead and copper. As this was the only location with copper above this level and actions related to lead would also address copper, I added a paragraph on copper for this faucet in the lead section.

Once reviewed Tracy Jo will work with OEA to get it finalized and provide back to me for final review before George distributes the report.

Stephen Busch, P.E.
MDEQ Lansing District Coordinator
Office of Drinking Water and Municipal Assistance
Lansing and Jackson District Supervisor
517-643-2314
sbuschs@michigan.gov