

Bergstrom, Carolyn (DEQ)

From: Patrick Williford <williford@dwsd.org>
Sent: Monday, October 06, 2014 7:41 PM
To: DEQ-DWMA-SEMI
Subject: LCR Report for Detroit
Attachments: 2014 Detroit LCR Report.pdf; 2014-10-06 LCR Results for Detroit.xlsx

I have attached a pdf copy to the MOR and to this email, but have also included the Detroit spreadsheet in this email.

Sincerely,

Patrick Williford
Principal Analytical Chemist
williford@DWSD.org
Office: 313.926.8127

Detroit Water & Sewerage Dept.
Water Quality Division
Water Works Park Administration Bldg., RM 207
10100 E. Jefferson Ave.
Detroit, MI 48214-3139

"In God we trust."

-The contents of this email may not reflect the opinion of the sender, nor have the contents' accuracy been verified.

-This electronic communication is covered by the Electronic Communications Privacy Act of 1986, Codified at 18 U.S.C. §§ 1367, 2510-2521, 2701-2710, 3121-3126. Also, see: <http://www.ftc.gov/privacy/subject/etbsub1.htm>
- Gramm-Leach-Bliley Act 15 USC, Subchapter I, Sec. 6801-6809

-Please use Email etiquette: Delete all email addresses in the body of the email before forwarding to eliminate address additions to spam lists. Use Bcc (Blind Copy) when sending email to multiple recipients who do not know each other so as to keep their addresses confidential.

Detroit (1800)

	Pb	Cu
0	0	0
1	0	0
2	0	0
3	0	0
4	0	0
5	0	0
6	0	0
7	0	0
8	0	0
9	0	0
10	0	0
11	0	0
12	0	0
13	0	5.3
14	0	5.4
15	0	5.7
16	0	5.9
17	0	6.1
18	0	6.1
19	0	6.7
20	0	7
21	0	7.1
22	0	7.9
23	0	8.8
24	0	9.5
25	0	10.1
26	0	10.2
27	0	11.8
28	0	12.5
29	0	12.8
30	0	13.8
31	0	14.6
32	0	16.9
33	0	17.1
34	0	17.1
35	0	18
36	0	18.8
37	0	19.1
38	0	24.2
39	0	25.1
40	0	26.6
41	0	27.8
42	0	30.6
43	0	31.9
44	0	35.7
45	0	43
46	0	52
47	0	54.6
48	0	59
49	0	60.2
50	2	70.3
51	2.2	74
52	2.4	77.8
53	2.7	92
54	3.2	191.8
55	3.4	202
56	4.2	202
57	5.4	232
90th	2.3	75.1
average	0.46	33.1
max	5.40	232.00