

Bergstrom, Carolyn (DEQ)

From: Bergstrom, Carolyn (DEQ)
Sent: Wednesday, November 12, 2014 9:47 AM
To: 'Mary Lynn Semegen'
Cc: 'williford@dwsd.org'
Subject: 2014 Lead and Copper Monitoring Results

We received your 2014 lead and copper monitoring results, reporting form, and certification of lead consumer notice. The results of your monitoring are as follows. Please retain for your records.

WSSN: 1800 Supply Name: City of Detroit

Action Levels	90 th Percentile	# of Samples Above Action Level
Lead 15 parts per billion (ppb)	2.3 ppb	0
Copper 1300 parts per billion (ppb)	75.1 ppb	0

These results must be reported on your 2014 Consumer Confidence Report (CCR) due to our office, your customers and the local health department by July 1, 2015. Also include the following statement in the CCR, regardless of the lead and copper levels:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF UTILITY] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://water.epa.gov/drink/info/lead>.

Please contact me if you have any questions.

Thank you,

Carolyn Bergstrom
 Environmental Quality Analyst
 Office of Drinking Water and Municipal Assistance
 Michigan Department of Environmental Quality
 27700 Donald Court
 Warren, MI 48092
 Phone: 586-753-3755
 Fax: 586-753-3831

	A	B	C
2			
3	Contact		
4	Christina Donaldson		
5	Amy LaChance		1 Detroit city, Michigan 2 Grand Rapids city, Michigan
6	Christina Donaldson		3 Warren city, Michigan
7	Christina Donaldson		4 Sterling Heights city, Michigan
8	Steve Busch		5 Ann Arbor city, Michigan
9	Steve Busch		6 Lansing city, Michigan
10	Steve Busch		7 Flint city, Michigan
11			
12	* Detroit, Warren, and Sterling Heights are customers of the Great Lakes Water Authority (GLWA). GLWA employs corrosion control treatment and is considered optimized.		
13	Detroit, Warren, and Sterling Heights receive water from GLWA that is considered optimized. Detroit, Warren, and Sterling Heights do not employ any additional treatment themselves.		