

From: Shekter Smith, Liane (DEQ)
Sent: Tuesday, August 25, 2015 1:56 PM
To: lwalters313@gmail.com
Cc: Busch, Stephen (DEQ); Devereaux, Tracy Jo (DEQ)
Subject: Follow Up from our Aug. 4th meeting

Dear Ms. Walters,

I wanted to update you regarding our Department's findings related to questions raised during our meeting at the Governor's office on August 4. I apologize for the delay in getting back to you.

Lead and Copper Monitoring

Regarding Flint lead and copper compliance monitoring for the January – June 2015 period, the City has confirmed that all lead and copper samples collected throughout the City, whether routine sites or customer requests, were sent to the State of Michigan lab for analysis. Individual sample results are provided to the property owner within 30 days of receiving the lab results in accordance with the Michigan Safe Drinking Water Act (Public Act 399, 1976 Administrative Rule 410(5)). Results from the State of Michigan lab are provided directly to our Office.

Staff have confirmed that the lead 90th percentile compliance calculation of 11 parts per billion is based on 69 samples that met the appropriate sampling location site criteria, and met the sample collection site and collection protocol requirements of the Safe Drinking Water Act for this monitoring period. A minimum of 60 samples were required for this monitoring period. As indicated during the meeting, the City's sampling for lead complies with the Action Level standard of 15 parts per billion, but based on the population served by the City and these results, the City will need to make a recommendation to the MDEQ on how they will fully optimize their corrosion control treatment. These next steps continue to follow the requirements of the Lead and Copper Rule.

From: Kaplan, Robert <kaplan.robert@epa.gov>
Sent: Friday, December 04, 2015 3:18 PM
To: Sygo, Jim (DEQ)
Subject: Attached -- Task Force Comments on Residential Sampling Protocol
Attachments: Task Force Comments on MDHHS Residential Sampling Protocol 12-4-15.pdf

Jim,

Thanks for giving the Task Force the opportunity to comment on the Residential Sampling Protocol. I've attached EPA's comments.

- Bob

Robert Kaplan
Deputy Regional Administrator
U.S. EPA Region 5
Phone: (312) 886-1499
Cell: PPI
Fax: (312) 692-2075