
From: Poy, Thomas <poy.thomas@epa.gov>
Sent: Friday, August 14, 2015 3:43 PM
To: Benzie, Richard (DEQ)
Cc: Busch, Stephen (DEQ); Shekter Smith, Liane (DEQ); Devereaux, Tracy Jo (DEQ); Henry, Timothy; Hyde, Tinka; Glowacki, Joanna; Crooks, Jennifer
Subject: RE: Draft 90th percentile letter
Attachments: Flint PbCu15-draft tpedit.doc

Liane/Richard/Steve: Thank you for the opportunity to provide input on the LCR letter to Flint. Attached are our suggested edits. I conferred with ORC and we believe that the Federal and Michigan rules allow the State to require specific treatment in lieu of a corrosion control study. Pat Cook asked about this during our last call. Flint would still have to do some monitoring as part of tweaking the treatment in order to optimize it.

Please let me know if you have questions about our comments/suggestions.

Tom

Tom Poy
 Chief, Ground Water and Drinking Water Branch
 USEPA - Region 5
 (312) 886-5991

From: Benzie, Richard (DEQ) [mailto:BENZIER@michigan.gov]
Sent: Wednesday, August 12, 2015 5:13 PM
To: Poy, Thomas; Hyde, Tinka
Cc: Busch, Stephen (DEQ); shokterl@michigan.gov; Devereaux, Tracy Jo (DEQ)
Subject: FW: Draft 90th percentile letter

Attached is our draft letter to Flint regarding their lead and copper monitoring results and 90th percentile determination for their initial 2 six-month LCR monitoring periods after the city converted from Detroit's conventional treatment of Lake Huron to softening of the Flint River. This letter includes our directions for the ensuing steps and our recommendations as far as corrosion control optimization.

Please provide any comments you may have by the close of business on Friday, August 14th. We realize this response time is short, but we intend to deliver this letter to the city on Monday, August 17th.

Thanks,
 Richard

Richard Benzie, P.E., Chief
 Field Operations Section
 Office of Drinking Water and Municipal Assistance, MDEQ
 517-284-6512

From: Busch, Stephen (DEQ)
Sent: Wednesday, August 12, 2015 11:06 AM

To: Benzie, Richard (DEQ)

Cc: Rosenthal, Adam (DEQ); Prysby, Mike (DEQ); Shekter Smith, Liane (DEQ); Cook, Pat (DEQ)

Subject: Draft 90th percentile letter

Richard,

Attached is our draft 90th percentile Pb/Cu letter for the City of Flint. Could you please forward this to Tinka Hyde and/or Tom Poy at EPA region V. We request any comments back by the close of business on Friday August 17. Thanks.

Stephen Busch, P.E.

MDEQ Lansing District Coordinator

Office of Drinking Water and Municipal Assistance

Lansing and Jackson District Supervisor

517-643-2314

buschs@michigan.gov