
From: Gohlke, Holly (DEQ)
Sent: Thursday, December 03, 2015 4:55 PM
To: Prysby, Mike (DEQ)
Cc: Philip, Kris (DEQ); Busch, Stephen (DEQ); Rosenthal, Adam (DEQ)
Subject: LCR Sampling-Sugar Tree WSSN: 6575
Attachments: SugarTree PbCu 1.pdf; SugarTree PbCu 2.pdf; SugarTree PbCu 3.pdf

Mike,

Attached is all the paperwork I have on Sugar Tree. Please review and advise on further action needed. My thoughts are that the building laundry faucets are improper sampling locations and the water supply must still collect 2 consecutive 6 month rounds (along with monitoring violations being issued). Let me know how I can further assist.

What I found for sampling history:

8/27/13	5/20/14	9/10/14	9/4/15
Office	Office faucet	Office faucet	Office faucet
Apt 608	Apt 608	Office Bath	Office Bath
Apt 251	Apt 251	Apt 104	Apt 104
Apt 327	Apt 327	Apt 330	Apt 330
Apt 607	Apt 607	Bldg 1 laundry	Bldg 1 laundry
	Apt 128	Bldg 2 laundry	Bldg 2 laundry
	Apt 402	Bldg 3 laundry	Bldg 3 laundry
	Apt 509	Bldg 4 laundry	Bldg 4 laundry
	Apt 331	Bldg 5 laundry	Bldg 5 laundry
	Apt 125	Bldg 6 laundry	Bldg 6 laundry