

As for the surge. Yes I spoke to the PM team yesterday and they are in the process of responding. I do not see any problems with providing a quick response.

From: Prysby, Mike (DEQ) [<mailto:PRYSBYM@michigan.gov>]
Sent: Wednesday, June 25, 2014 2:40 PM
To: Matt Raysin; Gotham, Daryl (DEQ)
Cc: Bloemker, Jon (DEQ); Busch, Stephen (DEQ); Osborn, Larry (LOSBOORN@wadetrim.com); John O'Malia; Elgar Brown (cbrownbear@broadstripe.net); Mike Winegard; Ed Tharp (Ed.Tharp@aecom.com)
Subject: RE: Contract S-4002 100% and S-4003 90% Submittals - MDEQ comments

Matt,

We do not have an objection with KWA wanting to use the more conservative leakage formula for the pipeline as opposed to the formula provided in AWWA C-604. We are also not opposed to the exclusion of the welded joints in the formula; however, since this results in a much lower leakage tolerance.... all welded joints need to be properly tested. The specification should clearly state an acceptable testing methodology such as radiography, sonograms, or magnetic particle testing.

Finally, it is our understanding that we will be receiving a response from Genesee County concerning our questions/comments from the updated surge analysis.

Michael Prysby, P.E.
 District Engineer
 Office of Drinking Water and Municipal Assistance
 517 290-8817

From: Matt Raysin [mailto:M_RAYSIN@gcdcwws.com]
Sent: Tuesday, June 24, 2014 6:05 PM
To: Gotham, Daryl (DEQ); Prysby, Mike (DEQ)
Cc: Bloemker, Jon (DEQ); Busch, Stephen (DEQ); Osborn, Larry (LOSBOORN@wadetrim.com); John O'Malia; Elgar Brown (cbrownbear@broadstripe.net); Mike Winegard; Ed Tharp (Ed.Tharp@aecom.com)
Subject: RE: Contract S-4002 100% and S-4003 90% Submittals - MDEQ comments

I would like to revisit the conversation this morning regarding the pressure test. The new leakage method based on AWWA 604-11 the 66" pipe would allow 55 gal/mile leakage in a 2 hour period. The current specified method in section 02315 would allow roughly 0.2 gal/mile leakage in a 2 hour period depending on the pressure (150 to 350 psi) and the (J) number of joints 1 per mile to 12 per mile (welded joints do not count so only the valves count on the 66" line, but if you count the hydrants, and air release valves, which are not normally counted, it could be 6-12 per mile depending on the section). Note that you would have to have about 165 joints per mile (an average of 1 joint every 32 feet) @ 350 psi to equal the 55 gal per 2 hours allowed by the new formula. For 150 psi, it would have to have the equivalent of 252 joints per mile to get the 55 gal leakage in 2 hours that is allowed by the new method. The current specification indicates to test at the pressure equal to the pressure class listed on the drawings, where the new version would say test at no more than 125% of the working pressured. The working pressure is not defined anywhere so is that the pressure class of the pipe, or the pressure within the pipe that is expected during operation?

The 60" would be somewhat similar to the 66", except the pressures would be lower on the 60" pipe.

With that being said will the MDEQ allow the current specifications to remain or do we need to still reference AWWA 604.11 for testing even though the allowable leakage is well above what we are allowing.

From: Gotham, Daryl (DEQ) [<mailto:GOTHAMD@michigan.gov>]
Sent: Thursday, June 19, 2014 3:34 PM
To: Prysby, Mike (DEQ); Osborn, Larry (LOSBORN@wadetrim.com); John O'Malia; Elgar Brown (cbrownbear@broadstreet.net); Matt Raysin
Cc: Bloemker, Jon (DEQ); Busch, Stephen (DEQ)
Subject: Contract S-4002 100% and S-4003 90% Submittals - MDEQ comments

We've completed the review of both projects and the only significant issues that resulted were the Leakage Test formulas that Mike Prysby identified in his review of S-4005. When the corrected specs are received, I am prepared to issue the permit for S-4002. If I have them by early afternoon on Monday, June 23rd, I can bring the permitted plans and specifications to the June 24th meeting. I'm willing to replace the corrected section of the spec into the previously submitted specs if that is easier. Emailing them to me would be fine.

Thanks,

Daryl J. Gotham, P.E.
Michigan Department of Environmental Quality
Office of Drinking Water & Municipal Assistance
Saginaw-Bay District Office
401 Ketchum Street, Suite B
Bay City, MI 48708
989-450-8146 (Phone)
989-891-9213 (Fax)