

Prysby, Mike (DEQ)

From: Michael Glasgow <mglasgow@cityofflint.com>
Sent: Tuesday, September 09, 2014 9:47 AM
To: Prysby, Mike (DEQ); Busch, Stephen (DEQ); Rosenthal, Adam (DEQ)
Cc: Brent Wright; Daugherty Johnson; Howard Croft
Subject: September 2014 Boil Water Notice Timeline
Attachments: Boil Water Advisory Event Timeline # 2.docx

Gentlemen,

Attached is a timeline of events that led us to the recent boil water notice. It shows all sampling and results from 9/2 thru today.

FYI:

I was just talking with a couple of employee's from the Water Service Center who have been helping us with our investigation of the the distribution system. It seems that they have found one of the possible causes of our recent issues. A 36" transmission main not far west of the treatment plant had a valve that was closed, and the 24" transmission main that leads west also has a valve that is closed. The 36" valve was opened, however the valve on the 24" is inoperable. With these valves closed, it appears the water leaving the plant has no direct route to the west side of the city (or the West Side Reservoir)

Mike Glasgow
City of Flint Water Plant