

pat

From: Deltoral, Miguel [<mailto:deltoral.miguel@epa.gov>]
Sent: Friday, April 24, 2015 11:59 AM
To: Cook, Pat (DEQ)
Cc: Poy, Thomas; Porter, Andrea
Subject: Re: Flint Corrosion Control?

What was the source water lead level?

Miguel A. Del Toral
 Regulations Manager
 U.S. EPA R5 GWDWB
 77 West Jackson Blvd, (WG-15J)
 Chicago, IL 60604
 Phone: (312) 886-5253

From: Cook, Pat (DEQ) <COOKP@michigan.gov>
Sent: Friday, April 24, 2015 10:43 AM
To: Deltoral, Miguel
Cc: Poy, Thomas; Porter, Andrea
Subject: RE: Flint Corrosion Control?

← STEVE 2/27/15 SAYS YES

Hi Miguel - Flint is currently not practicing corrosion control treatment at the WTP. When they started treating water at their WTP last spring, we placed them on full chart (100 sites) Pb/Cu monitoring for two consecutive 6 month periods. WQ monitoring is also being conducted. The first round of samples after switch-over from DWSO (July 1, 2014 – Dec 31, 2014) had 90th percentiles of 6 ppb for Lead and 110 ppb for Copper. The second round of samples (Jan 1, 2015 – June 30, 2015) is underway with approximately 20 of the 100 sample site results in. The highest lead result out of the 20 received thus far is 13 ppb.

Based on the matrix of recommended corrosion control study components for Large PWS's for both Lead and Copper, there are no additional requirements for the City of Flint based on the levels of lead and copper in the current source water and the results of the lead and copper distribution monitoring. The only provision of the Lead & Copper Rule which classifies the existing treatment of large PWSs as optimized for corrosion control is when the difference between the 90% Pb-TAP and Pb-POE is less than the lead practical quantitative level (PQL) for each six-month period of the initial monitoring program. By definition, the PQL for lead is 0.005 mg/L; and the lead value for the source water used in this determination is the highest source water lead concentration. If this condition is met, then no study or testing is required. We believe this condition has been met for Flint. However, we will re-evaluate this after the 2nd round of 6 month sampling is completed.

↑ JULY 24TH NOTE EXPLAINS ONLY GD NEEDED DUE TO PER DWP

EXPLANATION NEEDED FOR MR UNDERSTANDING

If you have any further questions, please contact the Lansing District Supervisor, Steve Busch at (517) 643-2314 or at buschs@michigan.gov.

Have a good (and hopefully warm) weekend!

Patrick Cook, P.E.
 Community Drinking Water Unit
 Office of Drinking Water & Municipal Assistance
 Michigan Department of Environmental Quality
 Phone: (517) 284-6514
cookp@michigan.gov