

Widigan, Robert (TREASURY)

From: Widigan, Robert (TREASURY)
Sent: Friday, October 03, 2014 10:25 AM
To: Howard Croft
Subject: RE: Water Issue

Good morning, Howard:

Thank you very much, this fits our needs.

Thank you,

Robert Widigan | Departmental Analyst | Office of Fiscal Responsibility
State of Michigan | Department of Treasury
430 W. Allegan Street, 3rd Floor | Lansing, MI 48922
(517) 335-2130 | WidiganR@michigan.gov

CONFIDENTIALITY NOTICE: This e-mail, and any attachments, is for the sole use of the intended recipient(s) and may contain information that is confidential and protected from disclosure under the law. Any unauthorized review, use, disclosure, or distribution is prohibited. If you are not the intended recipient, please contact the sender by reply e-mail, and delete/destroy all copies of the original message and attachments Thank you.

From: Howard Croft [<mailto:hcroft@cityofflint.com>]
Sent: Friday, October 03, 2014 10:12 AM
To: Widigan, Robert (TREASURY)
Subject: Water Issue

Rob,

Here is the overview of the recent boil water advisory, please review and see if this fits your needs.

Thank you,

--

Howard Croft
Public Works Director
City of Flint
1101 S. Saginaw Street
Flint, MI 48502
PH# 810.766.7346 Ext.2043
hcroft@cityofflint.com



CITY OF FLINT

Department of Public Works

Dayne Walling
Mayor

Darnell Earley, ICMA-CM, MPA
Emergency Manager

Howard Croft
Director

MEMORANDUM

TO: Darnell Earley, Emergency Manager
Dayne Walling, Mayor

FROM: Howard Croft, Public Works Director

DATE: September 16, 2014

RE: Recent Boil Water Advisory

Mr. Earley,

I have compiled a bullet point list of the pertinent events surrounding the recent boil water advisory in the City of Flint. I have separated the events into five categories and attempted to condense them into a comprehensive sequence for your review.

OVERVIEW

- On Friday September 5, 2014 the City of Flint issued a boil water advisory to residents in two of ten test areas around the city.
- The advisory was due to multiple positive tests for "total coliform" and the area covered approximately 9 square miles.
- On Sunday September 7, 2014 the City expanded the advisory to include another of the ten test areas due to a subsequent positive total coliform test.
- The boil water advisories were lifted on Tuesday September 9th at 5:00pm after consultation with the DEQ.